




OIL ANALYSIS REPORT

Sample Rating Trend



VISUAL METAL



Machine Id
FP60
 Component
Diesel Engine
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

The oil change at the time of sampling has been noted. We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

Moderate concentration of visible metal present. All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0014473	---	---
Sample Date	Client Info		15 Jun 2024	---	---
Machine Age	hrs	Client Info	11838	---	---
Oil Age	hrs	Client Info	900	---	---
Oil Changed	Client Info		Changed	---	---
Sample Status			ABNORMAL	---	---

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	---	---
Water	WC Method	>0.2	NEG	---	---
Glycol	WC Method		NEG	---	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	9	---	---
Chromium	ppm	ASTM D5185m >20	0	---	---
Nickel	ppm	ASTM D5185m >4	0	---	---
Titanium	ppm	ASTM D5185m	<1	---	---
Silver	ppm	ASTM D5185m >3	0	---	---
Aluminum	ppm	ASTM D5185m >20	2	---	---
Lead	ppm	ASTM D5185m >40	0	---	---
Copper	ppm	ASTM D5185m >330	4	---	---
Tin	ppm	ASTM D5185m >15	0	---	---
Vanadium	ppm	ASTM D5185m	0	---	---
Cadmium	ppm	ASTM D5185m	0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	74	---	---
Barium	ppm	ASTM D5185m	0	---	---
Molybdenum	ppm	ASTM D5185m	2	---	---
Manganese	ppm	ASTM D5185m	<1	---	---
Magnesium	ppm	ASTM D5185m	759	---	---
Calcium	ppm	ASTM D5185m	1508	---	---
Phosphorus	ppm	ASTM D5185m	1110	---	---
Zinc	ppm	ASTM D5185m	1352	---	---
Sulfur	ppm	ASTM D5185m	4795	---	---

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	5	---	---
Sodium	ppm	ASTM D5185m	26	---	---
Potassium	ppm	ASTM D5185m >20	6	---	---

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	0.2	---	---
Nitration	Abs/cm	*ASTM D7624 >20	8.0	---	---
Sulfation	Abs./1mm	*ASTM D7415 >30	19.3	---	---



OIL ANALYSIS REPORT







FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 20470	---	---
Particles >6µm	ASTM D7647	>5000	▲ 11151	---	---
Particles >14µm	ASTM D7647	>640	▲ 1898	---	---
Particles >21µm	ASTM D7647	>160	▲ 639	---	---
Particles >38µm	ASTM D7647	>40	▲ 99	---	---
Particles >71µm	ASTM D7647	>10	▲ 10	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 22/21/18	---	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414	>25	13.1	---	---
Base Number (BN)	mg KOH/g ASTM D2896		9.81	---	---

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	▲ MODER	---	---
Yellow Metal	scalar *Visual	NONE	NONE	---	---
Precipitate	scalar *Visual	NONE	NONE	---	---
Silt	scalar *Visual	NONE	NONE	---	---
Debris	scalar *Visual	NONE	NONE	---	---
Sand/Dirt	scalar *Visual	NONE	NONE	---	---
Appearance	scalar *Visual	NORML	NORML	---	---
Odor	scalar *Visual	NORML	NORML	---	---
Emulsified Water	scalar *Visual	>0.2	NEG	---	---
Free Water	scalar *Visual		NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt ASTM D445		14.0	---	---

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : KL0014473

Lab Number : 06215922

Unique Number : 11088786

Test Package : MOB 2 (Additional Tests: PrtCount, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 20 Jun 2024

Tested : 23 Jun 2024

Diagnosed : 23 Jun 2024 - Don Baldrige

IRON CLAD ENERGY

9015 W COUNTY RD 127

MIDLAND, TX

US 79706

Contact: TREVOR FRENETTE

T:

F: