

# **OIL ANALYSIS REPORT**



Machine Id

# 9213009 (S/N 1829) Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

# Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KC131208		
Sample Date		Client Info		24 May 2024		
Machine Age	hrs	Client Info		1436		
Oil Age	hrs	Client Info		1436		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum		ASTM D5185m	>10	۰ <1		
	ppm		>10	0		
Lead	ppm	ASTM D5185m				
Copper	ppm	ASTM D5185m	>50	8		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	27		
Calcium	ppm	ASTM D5185m	2	2		
Phosphorus	ppm	ASTM D5185m		2		
Zinc	ppm	ASTM D5185m		15		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		7		
Potassium	ppm	ASTM D5185m	>20	10		
Water	%	ASTM D6304	>0.05	0.020		
ppm Water	ppm	ASTM D6304	>500	206		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6147		
Particles >6µm		ASTM D7647	>1300	▲ 3350		
Particles >14µm		ASTM D7647	>80	▲ 455		
Particles >21µm		ASTM D7647		▲ 199		
Particles >38µm		ASTM D7647	>4	▲ 30		
Particles >71µm		ASTM D7647	>3	2		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		
		( )				history
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35		



Built for a lifetime

71 6

-= 5k

of particles

e 2k

0

12000

10000

800 (maa)

600 Water 400

200

0.50

(B/HO) Ê0.3

E 0.20

Pio 0.1

0.00

1000

600 Water (

4000

200

52

50

48

(D=04) 44 B

42

4(

38


Mau74/74

Abno

Abnormal

Mav24/2

Mav24/24





Contact/Location: Service Manager - FLOPALFL