




PROBLEM SUMMARY

Machine Id
VILTER CCUP-FGC
 Component
Compressor
 Fluid
 {not provided} (--- GAL)

Sample Rating Trend




INSOLUBLES



COMPONENT CONDITION SUMMARY

▲ Varnish Potential



RECOMMENDATION

We recommend that you use electrostatic or in-depth filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status		SEVERE	SEVERE	NORMAL
MPC Varnish Potential	Scale ASTM D7843 >15	▲ 58	▲ 59	8

Customer Id: NORRALNC
 Sample No.: WC0896678
 Lab Number: 06216856
 Test Package: AOM 1



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.
Filter Fluid	---	---	?	We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level.

HISTORICAL DIAGNOSIS

INSOLUBLES



30 Apr 2024 Diag: Doug Bogart

We recommend that you use electrostatic or in-depth filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The water content is negligible. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil.

view report



NORMAL



16 Jan 2024 Diag: Doug Bogart

Resample at the next service interval to monitor. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates acceptable levels of varnish present. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



INSOLUBLES



13 Sep 2023 Diag: Doug Bogart

We recommend that you use electrostatic or in-depth filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The water content is negligible. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



INSOLUBLES



Machine Id
VILTER CCUP-FGC
 Component
Compressor
 Fluid
 {not provided} (--- GAL)

DIAGNOSIS

▲ Recommendation

We recommend that you use electrostatic or in-depth filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The water content is negligible. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0896678	WC0896681	WC0896671
Sample Date	Client Info		20 Jun 2024	30 Apr 2024	16 Jan 2024
Machine Age	hrs	Client Info	104000	104000	104000
Oil Age	hrs	Client Info	104000	104000	104000
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	<1	0
Chromium	ppm	ASTM D5185m >5	<1	<1	<1
Nickel	ppm	ASTM D5185m	<1	<1	0
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >15	3	1	2
Lead	ppm	ASTM D5185m >65	<1	<1	0
Copper	ppm	ASTM D5185m >65	<1	<1	<1
Tin	ppm	ASTM D5185m >10	<1	<1	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	1	0	0
Molybdenum	ppm	ASTM D5185m	<1	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m	<1	<1	0
Calcium	ppm	ASTM D5185m	0	5	0
Phosphorus	ppm	ASTM D5185m	32	44	46
Zinc	ppm	ASTM D5185m	2	0	0
Sulfur	ppm	ASTM D5185m	288	163	182

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >35	<1	<1	0
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	1	1	1
Water	%	ASTM D6304 >0.1	0.001	0.002	0.004
ppm Water	ppm	ASTM D6304 >1000	12	18	50


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	577	2591	1203
Particles >6µm	ASTM D7647	>2500	195	406	428
Particles >14µm	ASTM D7647	>320	20	36	66
Particles >21µm	ASTM D7647	>80	5	15	24
Particles >38µm	ASTM D7647	>20	0	1	2
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	16/15/11	19/16/12	17/16/13




OIL ANALYSIS REPORT


▲ Varnish Potential




Remaining Life (RULER)




Particle Count



Acid Number



Water (KF)




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.10	0.13	0.082
Anti-Oxidant 1	%	ASTM D6971	<25	67	60	83
Anti-Oxidant 2	%	ASTM D6971	<25	31	36	69
MPC Varnish Potential	Scale	ASTM D7843	>15	▲ 58	▲ 59	8

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		105	103	102

SAMPLE IMAGES



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0896678

Lab Number : **06216856**

Unique Number : 11089720

Test Package : AOM 1 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 21 Jun 2024

Tested : 05 Jul 2024

Diagnosed : 05 Jul 2024 - Doug Bogart

NORTH CAROLINA STATE UNIVERSITY

621 MOTOR POOL DR, FACILITIES DIVISION WAREHOUSE

RALEIGH, NC


US 27607

Contact: PAUL WALKER

apwalke3@ncsu.edu

T: (919)513-3646

F:



MPC (Varnish Test)



Sample Color & Clarity



This page left intentionally blank