

OIL ANALYSIS R

Machine Id KAESER ASD 40T 5493667 (S/N

Compressor Fluic

KAESER SIGMA (OEM) S-460 (--- LTR)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Appearance is hazy. There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SIS REPC)RT					WATER
7 (S/N 1148	3)			DUD Judozi Augžiozz		
SAMPLE INFORM	NOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		KC06216881	KC05994386	KC05883344
Sample Date		Client Info		03 Jun 2024	12 Oct 2023	05 Jun 2023
Machine Age	hrs	Client Info		37657	33305	30903
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	<1	0
Nickel	ppm	ASTM D5185m	>3	<1	0	<1
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	3	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	9	8	14
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	1	20	0
Molybdenum	ppm	ASTM D5185m	00	، <1	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	<1	4	8
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	_	2	36	0
Zinc	ppm	ASTM D5185m		2	25	34
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		0	6	0
Potassium	ppm	ASTM D5185m	>20	2	0	2
Water	%	ASTM D6304	>0.05	0.068	0.008	0.042
ppm Water	ppm	ASTM D6304	>500	680	89.6	423.3
FLUID CLEANLIN	VESS	method	limit/base	current	history1	history2


Sample Rating Trend


FLUID CLEANLINE	SS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1096	11898	5996
Particles >6µm		ASTM D7647	>1300	597	4 001	1 760
Particles >14µm		ASTM D7647	>80	e 102	4 82	A 226
Particles >21µm		ASTM D7647	>20	<mark> </mark> 34	1 74	A 77
Particles >38µm		ASTM D7647	>4	6 5	1 3	3
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	e 17/16/14	1 /19/16	2 0/18/15
FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.36	0.36





OIL ANALYSIS REPORT












VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	🛑 HAZY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.3	44.8	44.4
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						3

Bottom





To discuss this sample report, contact Customer Service at 1-800-237-1369.

Test Package : IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: FIEEAS [WUSCAR] 06216881 (Generated: 06/26/2024 16:47:42) Rev: 1

Certificate 12367

Contact/Location: ? ? - FIEEAS Page 2 of 2

Contact:

T:

F: