


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

7842554 (S/N 1134)Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar2022	Aug2022 Jan2023	Jun2023 Dec2023	May2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018344	KCPA009238	KCP34634
Sample Date		Client Info		30 May 2024	07 Dec 2023	27 Jun 2023
Machine Age	hrs	Client Info		19232	16010	12851
Oil Age	hrs	Client Info		3000	0	3024
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	0	1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	2	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	5	5	3
Lead	ppm	ASTM D5185m	>10	1	0	0
Copper	ppm	ASTM D5185m	>50	17	7	9
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	100	8	0	2
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	3	0	<1
Zinc	ppm	ASTM D5185m	0	51	0	29
Sulfur	ppm	ASTM D5185m	23500	20460	16934	22860
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	0
Sodium	ppm	ASTM D5185m	720	2	0	2
Potassium	ppm	ASTM D5185m	>20	3	0	1
Water	%	ASTM D6304	>0.05	0.008	0.006	0.008
ppm Water	ppm	ASTM D6304	>500	87	60	89.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		37255	7344	14008
Particles >6µm		ASTM D7647	>1300	17163	1324	<u>A</u> 2837
Particles >14µm		ASTM D7647	>80	1545	60	117
Particles >21µm		ASTM D7647	>20	4 340	13	22
Particles >38µm		ASTM D7647	>4	<u>▲</u> 12	1	1
Particles >71µm		ASTM D7647		1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/21/18</u>	20/18/13	<u>△</u> 21/19/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.47	0.45	0.45



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

Unique Number : 11089768

: KCPA018344 : 06216904

Received **Tested** Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 21 Jun 2024 : 24 Jun 2024 Diagnosed

: 24 Jun 2024 - Doug Bogart

US 75208 Contact: Service Manager

2202 CHALK HILL DR

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: BESDAL [WUSCAR] 06216904 (Generated: 06/24/2024 14:01:45) Rev: 2

Contact/Location: Service Manager - BESDAL

T:

F:

DALLAS, TX