


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER BSD 50 1887743 (S/N 2017)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

### **DIAGNOSIS**

### Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2017	Jul2018	Aug2020 Nov2022	Jun 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012959	KCP47080	KCP10477
Sample Date		Client Info		03 Jun 2024	27 Nov 2022	15 Aug 2020
Machine Age	hrs	Client Info		50844	47189	40904
Oil Age	hrs	Client Info		0	1377	2880
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	2	2
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	3	2	0
Lead	ppm	ASTM D5185m	>10	<1	<1	0
Copper	ppm	ASTM D5185m	>50	12	8	17
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	15
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	<1	15	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	2	21	2
Zinc	ppm	ASTM D5185m	0	34	99	29
Sulfur	ppm	ASTM D5185m	23500	19950	22541	18528
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	2
Sodium	ppm	ASTM D5185m		0	2	3
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304		<u> </u>	0.014	0.012
ppm Water	ppm	ASTM D6304	>500	<u>▲</u> 1620	142.9	124.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		1106	1381	19366
Particles >6µm		ASTM D7647	>1300	602	153	<b>4</b> 969
Particles >14μm		ASTM D7647	>80	<u> </u>	3	<u>^</u> 264
Particles >21µm		ASTM D7647	>20	<b>35</b>	1	<b>△</b> 45
Particles >38μm		ASTM D7647	>4	<u> </u>	0	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>17/16/14</b>	18/14/9	▲ 19/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



## OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number Unique Number : 11089781

: KCPA012959 : 06216917

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 21 Jun 2024 Tested : 26 Jun 2024

Diagnosed Test Package : IND 2 ( Additional Tests: KF, PrtCount )

: 26 Jun 2024 - Jonathan Hester

203 W OVERLY DR LAKE DALLAS, TX US 75065

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T:

F: