

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SK 15 8211001 (S/N 1813)

Component Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- LTR)

DIAGNOSIS

Recommendation

There is too much water present in this sample to perform a particle count. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Free water present. Excessive free water present.


Fluid Condition


The AN level is acceptable for this fluid.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017372	KCP40307D	
Sample Date		Client Info		06 Jun 2024	04 Nov 2022	
Machine Age	hrs	Client Info		4247	2027	
Oil Age	hrs	Client Info		4893	2027	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	2	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	<1	
Aluminum	ppm	ASTM D5185m	>10	3	0	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	18	8	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	2	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	19	47	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		<1	4	
Zinc	ppm	ASTM D5185m		23	10	
Sulfur	ppm	ASTM D5185m		19262	21159	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	5	<1	
Sodium	ppm	ASTM D5185m		<1	13	
Potassium	ppm	ASTM D5185m	>20	2	2	
Water	%	ASTM D6304	>0.05	A 0.176	0.043	
ppm Water	ppm	ASTM D6304	>500	 1760	434.2	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			12284	
Particles >6µm		ASTM D7647	>1300		4 051	
Particles >14µm		ASTM D7647	>80		A 262	
Particles >21µm		ASTM D7647	>20		A 38	
Particles >38µm		ASTM D7647	>4		2	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		2 1/19/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.34	




OIL ANALYSIS REPORT









To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

mdo

ŝ

Laboratory

Sample No.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate 12367

T:

F: