

## **OIL ANALYSIS REPORT**

Area PG-46 [293104] Machine Id INGERSOLL RAND CBV116097 - CIMTECH PLASTIC Component

Component Compressor

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

## Wear


All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001809		
Sample Date		Client Info		17 Jun 2024		
Machine Age	hrs	Client Info		51867		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	۷	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		584		
Zinc	ppm	ASTM D5185m		23		
Sulfur	ppm	ASTM D5185m		372		
CONTAMINANTS	i -	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		5		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.14		



# **OIL ANALYSIS REPORT**

Acid Number 0.16 0.14 0.14 0.12 0.10 K0H/d) 0.08 0.06 Pig 0.04 0.02 0.00 7/24 Junl Viscosity @ 40°C 52



			method				history2
W	hite Metal	scalar	*Visual	NONE	NONE		
Y	ellow Metal	scalar	*Visual	NONE	NONE		
Ρ	recipitate	scalar	*Visual	NONE	NONE		
S	ilt	scalar	*Visual	NONE	NONE		
D	ebris	scalar	*Visual	NONE	NONE		
	and/Dirt	scalar	*Visual	NONE	NONE		
	ppearance	scalar	*Visual	NORML	NORML		
	dor	scalar	*Visual	NORML	NORML		
	mulsified Water	scalar	*Visual	>0.1	NEG		
_	ree Water	scalar	*Visual		NEG		
	FLUID PROPER		method	limit/base	current	history1	history
_	isc @ 40°C	cSt	ASTM D44	5	43.2		
	SAMPLE IMAGE	S	method	limit/base	current	history1	history
С	olor					no image	no image
в	ottom					no image	no image
10 - 8 - Edd 4 - 2 - 0	Ferrous Alloys			Jun17/24			
	tiron chromium nickel HZZLIUN Non-ferrous Meta	ls		Jun17/24			
	Non-ferrous Meta	ls		Jun17/24	Acid Number		
10 - 8 - 8 - 8 - 9 - 9 - 9 - 9 - 9 - 9 - 9	tiron chromium nickel HZZLIUN Non-ferrous Meta	ls		Jun17/24			
10 - 8 - 8 - 8 - 9 - 9 - 9 - 9 - 9 - 9 - 9	Non-ferrous Meta	ls		Jun17/24			
	Non-ferrous Meta	ls		Jun17/24			
10	hon-ferrous Meta	ls		ad Mumber (mg K0H/g) 50.0 km/g			
10	Non-ferrous Meta	ls					
	Non-ferrous Meta	11 Madiso Recei Teste	ived :	ry, NC 27513 21 Jun 2024 24 Jun 2024	Jun 17/24	-	RE DYNAMI RING LAKE ITASCA
	Non-ferrous Meta	11 Madiso Recei Teste	ived :	HOLD THE PERSON AND ADDRESS OF AD	Jun 17/24	225 SPI	RING LAKE

To discuss this sample report, con \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: ED DIENER - UCFLUSCH

F: