

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area **PG** 46 [290050] Machine Id **PNEUTECH 00050242 - ERMCO** Component

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		UFD0001990	UFD0000739		
Sample Date		Client Info		07 Jun 2024	01 Mar 2024		
Machine Age	hrs	Client Info		3905	0		
Oil Age	hrs	Client Info		0	0		
Oil Changed		Client Info		Not Changd	Changed		
Sample Status				NORMAL	NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2	
Water		WC Method	>0.1	NEG	NEG		
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	1	0		
Chromium	ppm	ASTM D5185m	>10	0	<1		
Nickel	ppm	ASTM D5185m		0	0		
Titanium	ppm	ASTM D5185m		0	0		
Silver	ppm	ASTM D5185m		0	0		
Aluminum	ppm	ASTM D5185m	>25	<1	0		
Lead	ppm	ASTM D5185m	>25	0	0		
Copper	ppm	ASTM D5185m	>50	1	<1		
Tin	ppm	ASTM D5185m	>15	0	<1		
Vanadium	ppm	ASTM D5185m		<1	0		
Cadmium	ppm	ASTM D5185m		<1	0		
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0		
Barium	ppm	ASTM D5185m		0	0		
Molybdenum	ppm	ASTM D5185m		0	0		
Manganese	ppm	ASTM D5185m		<1	0		
Magnesium	ppm	ASTM D5185m		0	<1		
Calcium	ppm	ASTM D5185m		<1	2		
Phosphorus	ppm	ASTM D5185m		316	298		
Zinc	ppm	ASTM D5185m		30	31		
Sulfur	ppm	ASTM D5185m		269	256		
CONTAMINANTS	;	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	1	<1		
Sodium	ppm	ASTM D5185m		3	2		
Potassium	ppm	ASTM D5185m	>20	1	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.14	0.22		



38 Mar1/24 -

OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2	
	White Metal	scalar	*Visual	NONE	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE	NONE		
	Silt	scalar	*Visual	NONE	LIGHT	NONE		
	Debris	scalar	*Visual	NONE	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE		
Jun7/24	Appearance	scalar	*Visual	NORML	NORML	NORML		
٦ ٦	Odor	scalar	*Visual	NORML	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG		
	Free Water	scalar	*Visual		NEG	NEG		
	FLUID PROPERT	IES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		47.7	46.9		
	SAMPLE IMAGES	5	method	limit/base	current	history1	history2	
-+++	Color				- <u>(</u>		no image	
	Bottom						no image	
	Ferrous Alloys			Jun7/24				
	Non-ferrous Metal	S						
	Mar1/24			Jun7/24				
	Viscosity @ 40°C				Acid Number	-		
	Abnormal			(0,25 (0,020 (0,020) (
	50 +			2 U.20				
	(Co.0+) 45 ts			· · · · · · · · · · · · · · · · · · ·	1			
	40 - Abnormal			P0.05				
	35				4			
	Mar1/24			Jun7/24	Mar1/24		401 mil.	
Laboratory Sample No. Lab Number Unique Number Test Package	: UFD0001990 : 06216993 : 11089857 : IND 2	Recei Teste Diagr	Madison Ave., Cary, NC 27513 Received : 21 Jun 2024 Tested : 24 Jun 2024 Diagnosed : 24 Jun 2024 - Wes Davis ce at 1-800-237-1369. 2025 scope of accreditation.			FLUID-AIRE DYNAMIC 225 SPRING LAKE DF ITASCA, II US 6014 Contact: ED DIENEF ed.diener@fluidairedynamics.com T: (847)678-8388		

Contact/Location: ED DIENER - UCFLUSCH