

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area S-46 [283199] ATLAS COPCO 16475 - GROTH MFG

Component Compressor

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000718		
Sample Date		Client Info		07 Jun 2024		
Machine Age	hrs	Client Info		17386		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	J	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS					biotomut	biotom/0
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	<1		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	<1		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		2		
Phosphorus	ppm	ASTM D5185m		388		
Zinc	ppm	ASTM D5185m		128		
Sulfur	ppm	ASTM D5185m		112		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	<1		
Sodium	ppm	ASTM D5185m		6		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.08		



38 Jun7/24

OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Jun7/24	Appearance	scalar	*Visual	NORML	NORML		
л°	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		44.7		
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2
+ 12/muL	Color				•	no image	no image
	Bottom					no image	no image
	Non-ferrous Metal			Jun7/24			
	Ron-remous Metal	5					
	0 1 2 2 7 1 2 7			Jun7/24			
	Viscosity @ 40°C				Acid Numb	er	
	50 - 9 			.0 .0000000000000000000000000000000000	08 - 06 - 04 - 02 -		
	35 4 +2/Lun			4 0.0	Jun7/24		AC F mil
Laboratory Sample No. Lab Number Unique Number Test Package	: 11089861 Diagnosed : 24 Jun 202				24 225 SPRING LAKE 24 ITASCA 24 - Wes Davis US 60 Contact: ED DIEN		
discuss this sample report, Denotes test methods that a tements of conformity to sp	are outside of the ISO 1	7025 sco	ope of accred	litation.			edynamics.cor (847)678-838 F

Contact/Location: ED DIENER - UCFLUSCH