

OIL ANALYSIS REPORT

Area PG46 [284912] **PNEUTECH AK100018446 - PRECISION ZONE**

Component Compressor

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001247	UFD0000022	
Sample Date		Client Info		05 Jun 2024	26 Sep 2023	
Machine Age	hrs	Client Info		3823	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	۷	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	0	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	0	0	
Tin	ppm	ASTM D5185m	>15	0	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m		<1	1	
Calcium	ppm	ASTM D5185m		0	1	
Phosphorus	ppm	ASTM D5185m		310	573	
Zinc	ppm	ASTM D5185m		36	33	
Sulfur	ppm	ASTM D5185m		92	133	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	12	
Sodium	ppm	ASTM D5185m		2	<1	
Potassium	ppm	ASTM D5185m	>20	1	<1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.18	0.11	



OIL ANALYSIS REPORT

Acid Number 0.20 Acid Number (mg K0H/g) 0.10 0.02 0.00 Sep26/23 Viscosity @ 40°C 52. Abnormal 50 48 (0-0+) 44 55 42 40 Abnorma 38 Sep26/23

	VISUAL		method				history2	
	White Metal	scalar	*Visual	NONE	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE		
Jun5/24	Appearance	scalar	*Visual	NORML	NORML	NORML		
- -	Odor	scalar	*Visual	NORML	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG		
1	Free Water	scalar	*Visual		NEG	NEG		
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		41.3	47.9		
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
Jun5/24	Color						no image	
	Bottom						no image	
	Ferrous Alloys	ls		Jun5/24				
	Viscosity @ 40°C			Jun5/24				
	55 T			0.20	Acid Number			
	50 - Abnormal			HOX 0.15				
	(J) - 0+ 45 75			0.20 1.10 0.15 0.10 0.00 Vmmber 0.00 Vmmbe				
	る 40 Abnormal			- Inde				
				Z 0.05				
	35 4							
	Sep 26/23			Jun5/24	Sep 26/23			
Laboratory Sample No. Lab Number Unique Number Test Package	: UFD0001247 : 06217005 : 11089869 : IND 2	Rece Teste Diagr	I Madison Ave., Cary, NC 27513 Received : 21 Jun 2024 Tested : 24 Jun 2024 Diagnosed : 24 Jun 2024 - Wes Davis <i>ce at 1-800-237-1369.</i> 7025 scope of accreditation.			FLUID-AIRE DYNAMIC 225 SPRING LAKE D ITASCA, I US 6014 Contact: ED DIENE ed.diener@fluidairedynamics.cor T: (847)678-838		

Report Id: UCFLUSCH [WUSCAR] 06217005 (Generated: 06/24/2024 13:44:07) Rev: 1

Contact/Location: ED DIENER - UCFLUSCH