


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 9319420 (S/N 2169) Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

## Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Mar2024	Jun 2024		
SAMPLE INFORM	ΛΑΤΙΩΝΙ	method	limit/base	current	history1	history2
	MATION	Client Info	IIIIIIVDase	KC124676	KC125703	
Sample Number Sample Date		Client Info		12 Jun 2024	13 Mar 2024	
Machine Age	hrs	Client Info		443	269	
Oil Age	hrs	Client Info		0	0	
Oil Changed	0	Client Info		N/A	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	<1	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	3	<1	
Lead	ppm	ASTM D5185m	>10	1	<1	
Copper	ppm	ASTM D5185m	>50	3	1	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	14	41	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	70	77	
Calcium	ppm	ASTM D5185m	2	0	6	
Phosphorus	ppm	ASTM D5185m		6	3	
Zinc	ppm	ASTM D5185m		8	0	
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		14	16	
Potassium	ppm	ASTM D5185m	>20	16	9	
Water	%	ASTM D6304	>0.05	0.029	0.033	
ppm Water	ppm	ASTM D6304	>500	290	332	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		19266	3336	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 7939	832	
Particles >14μm		ASTM D7647	>80	<u> </u>	64	
Particles >21µm		ASTM D7647		<u>^</u> 384	19	
Particles >38µm		ASTM D7647	>4	<u>^</u> 6	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/20/18	19/17/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.38	



# **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

: KC124676 Lab Number : 06217296 Unique Number : 11090160 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 21 Jun 2024 **Tested** : 25 Jun 2024

Diagnosed : 25 Jun 2024 - Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: Contact/Location: Service Manager - FROCLE

12770 44TH ST N

US 33762

T:

CLEARWATER, FL

Contact: Service Manager