


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SM 11 2242832 (S/N 1046)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2017 A	ug2018 Mar2019 Oct201	19 Sep 2020 Nov2022 Nov2023	Jun2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA019292	KCPA011492	KCP47083
Sample Date		Client Info		17 Jun 2024	29 Nov 2023	07 Nov 2022
Machine Age	hrs	Client Info		52854	50699	46698
Oil Age	hrs	Client Info		3000	0	3000
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	0	3
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	3	0	0
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	2	5	8
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	28	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	67	0	<1
Calcium	ppm	ASTM D5185m	0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	<1	0	<1
Zinc	ppm	ASTM D5185m	0	15	0	0
Sulfur	ppm	ASTM D5185m	23500	21028	17724	24160
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	<1
Sodium	ppm	ASTM D5185m		2	<1	0
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304		0.028	0.004	0.009
ppm Water	ppm	ASTM D6304	>500	287	49	99.1
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		87073	15766	129355
Particles >6µm		ASTM D7647	>1300	43823	<u>▲</u> 10703	<u></u> 55845
Particles >14μm		ASTM D7647	>80	<u>^</u> 6643	<u>4655</u>	<u></u> 8404
Particles >21µm		ASTM D7647	>20	<u> </u>	<u>^</u> 2120	<u>▲</u> 1132
Particles >38µm		ASTM D7647	>4	<u>^</u> 28	<u>^</u> 86	<u> </u>
Particles >71µm		ASTM D7647	>3	1	2	0
Oil Cleanliness		ISO 4406 (c)	>17/13	23/20	<u>^</u> 21/19	<u>\$\text{23}\) 23/20</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA019292 : 06217302 Unique Number : 11090166

Received : 21 Jun 2024 **Tested** Diagnosed

: 25 Jun 2024

: 25 Jun 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

twhite@andrewmotors.com T: F:

ANDREW CHEVROLET dba ANDREW AUTO BODY

1621 W LA SALLE AVE

GLENDALE, WI

Contact: T. WHITE

US 53209