

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 7942001

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC106345	KC100388	
Sample Date		Client Info		24 May 2024	31 Mar 2023	
Machine Age	hrs	Client Info		5414	3511	
Oil Age	hrs	Client Info		1903	3511	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	3	0	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m		11	9	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	1	0	
Molybdenum	ppm	ASTM D5185m	30	، <1	<1	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	24	32	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus		ASTM D5185m	2	0	6	
Zinc	ppm ppm	ASTM D5185m		27	3	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm		>25	2	<1	
Sodium	ppm	ASTM D5185m		13	10	
Potassium	ppm	ASTM D5185m	>20	5	3	
Water	%	ASTM D6304	>0.05	0.018	0.020	
ppm Water	ppm	ASTM D6304	>500	187	208.9	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4547		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	<u> </u>		
Particles >21µm		ASTM D7647	>20	<mark>/</mark> 39		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	1 9/18/15		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.25	0.26	



OIL ANALYSIS REPORT

Particle Trend		VISUAL		method	limit/base	current	history1	history2
4μm 6μm		White Metal	scalar	*Visual	NONE	NONE	LIGHT	
**************************************		Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
		Precipitate	scalar	*Visual	NONE	NONE	NONE	
		Silt	scalar	*Visual	NONE	NONE	NONE	
		Debris	scalar	*Visual	NONE	NONE	A MODER	
		Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
1/23 -	4/24	Appearance	scalar	*Visual	NORML	NORML	NORML	
Mar31/23	May24/24	Odor	scalar	*Visual	NORML	NORML	NORML	
		Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
Water (KF)		Free Water	scalar	*Visual		NEG	NEG	
Severe		FLUID PROPER		method	limit/base	current	history1	history
		Visc @ 40°C	cSt	ASTM D445	46	43.8	44.9	
		SAMPLE IMAGE		method	limit/base	current	history1	history
		SAIVIF LE IIVIAGE	.5	method		Current	Thistory	TISTOL 24
Abnormal 1/2/3	May24/24	Color						no image
≥ Acid Number	×							
Base		Bottom						no image
		GRAPHS						
		Ferrous Alloys				Particle Count		
		10iron			491,520			ľ
	¥ C	6			122,880	-		
Mar31/23	146-				30,720			
M	N.N.	2						
Water (KF)		0			7,680			-
Severe		Mar31/23			May24,24 s (per 1 m]			
		Mar			May es (pe	1		
		Non-ferrous Meta	ls		May24/24 particles (per 1 ml) 086			
		15 copper			jo jaj 120			
		10 - tead			jo aquinu			
Abnormal		E d			30	-		t
Q	~	5			8	-		
Mar31/23	iere.	0			_	Bereve mal		
	h.h	Mar31/23			24/24			1
Viscosity @ 40°C		Mar3			May24/24			
Abnormal		Viscosity @ 40°C			4	ونام Acid Number	14μ 21μ	38µ 71j
		⁵⁵			0.50	т :		
Base		50 - Abnormal			0.50 Hoy 0.40	Base	*****	
		45 Abnormal			ຍັ 0.30			
		40 - Abnormal			- e 0.20			
Abnormal					Pico Acid Nurr			
		35 L +			0.00			
31/23	VC P	Mar31/23			May24/24	Mar31//		
Mar31,	- W	2			×	2		
		: WearCheck USA - 50 : KC106345	Rece	ved : 21	l Jun 2024	H		1 62ND AVI
	Lab Number Unique Number	: 11090172	Teste Diagr		5 Jun 2024 Jun 2024 - Don	Baldridge		LAS PARK, US 337
Certificate L2367	Lab Number Unique Number Test Package	: 11090172 : IND 2	Diagr	iosed : 25	Jun 2024 - Don	Baldridge		
To discuss thi	Lab Number Unique Number Test Package s sample report,	: 11090172	Diagr	iosed : 25 200-237-1369	Jun 2024 - Don 9.	Baldridge		US 337

Report Id: HARPINKC [WUSCAR] 06217308 (Generated: 06/25/2024 17:27:09) Rev: 1

Contact/Location: Service Manager - HARPINKC