

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER 7285506

Component Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ma	2022	Apr2023 May20	24	
CAMPLE INFORM	AATION		line it the same		la tarta mari	la la tama O
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014494	KCP52740	KCP41027
Sample Date		Client Info		29 May 2024	05 Apr 2023	23 Mar 2022
Machine Age	hrs	Client Info		2402	1778	1130
Oil Age	hrs	Client Info		0	400	600
Oil Changed		Client Info		Not Changd	Changed	Changed
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m		<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	3	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	1	0	<1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	68	19	51
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	87	77	77
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	4	0	0
Zinc	ppm	ASTM D5185m	0	3	0	<1
Sulfur	ppm	ASTM D5185m	23500	21012	24007	18061
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	<1
Sodium	ppm	ASTM D5185m		4	6	9
Potassium	ppm	ASTM D5185m	>20	2	0	0
Water	%	ASTM D6304	>0.05	0.012	0.008	0.019
ppm Water	ppm	ASTM D6304	>500	120	83.4	198.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2167	1754	28106
Particles >6µm		ASTM D7647	>1300	797	410	<u>▲</u> 13557
Particles >14μm		ASTM D7647	>80	78	18	▲ 1960
Particles >21µm		ASTM D7647	>20	17	5	▲ 463
Particles >38μm		ASTM D7647	>4	0	0	△ 28
Particles >71µm		ASTM D7647	>3	0	0	2
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/17/13	18/16/11	<u>22/21/18</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.32	0.31	0.39



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

: 06217325 Unique Number : 11090189

: KCPA014494

Received **Tested** Diagnosed

: 21 Jun 2024 : 25 Jun 2024

: 25 Jun 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1200 HAZEL ST LEADVILLE, CO US 80461

Contact: L. RODIGUEZ Irodiguez@co.lake.co.us

T:

F: