

## **OIL ANALYSIS REPORT**

....I....I....I...I...I...

### NORMAL

Machine Id

# FES TYSHOUP RC-13 (S/N T0325)

Component Refrigeration Compressor Fluic

USPI ALT-68 SC (--- GAL)

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	<b>MATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0013133	USP0007748	USP0003097
Sample Date		Client Info		20 Jun 2024	21 Feb 2024	02 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	<1	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>3	0	<1	0
Lead	ppm	ASTM D5185m	>2	۰ <1	0	0
Copper	ppm	ASTM D5185m	>8	<1	<1	0
Tin		ASTM D5185m	>0 >4	<1	<1	0
Vanadium	ppm	ASTM D5185m	>4	<1	0	0
	ppm					
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		<1	<1	0
Calcium	ppm	ASTM D5185m		0	1	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	<1	0
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.01	0.006	0.007	0.004
ppm Water	ppm	ASTM D6304	>100	66	79	45.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1715	2365	5827
Particles >6µm		ASTM D7647	>2500	459	383	1039
Particles >14µm		ASTM D7647	>320	16	12	23
Particles >21µm		ASTM D7647	>80	1	4	6
Particles >38µm		ASTM D7647	>20	0	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	18/16/11	18/16/11	20/17/12
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.014	0.014


Contact/Location: SERVICE MANAGER - TYSHOU Page 1 of 2





# **OIL ANALYSIS REPORT**












VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT		method	limit/base	current	history1	history2
					THSIOLY I	riistor yz
Visc @ 40°C	cSt	ASTM D445	65.6	65.1	66.0	65.4
	cSt					
Visc @ 40°C	cSt	ASTM D445	65.6	65.1	66.0	65.4

GRAPHS Particle Count Ferrous Alloys 491 520 122,88 30.72 20 28 4406 ah 20/ Der 1,920 1999 Cle Non-ferrous Metals 480 6 120 2 de 30 av15/23 14 Viscosity @ 40°C Acid Number 75 (<sup>B</sup>/HOX 0.04 Ab Ē 0.03 · 문 0.02 Acid Num 0.01 Abnorma B 55 May15/23 un29/21 eb20/14 m28/20 eb20/1 Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 **TYSON -HOUSTON -USP - TYSHOUPOR** Sample No. : USP0013133 Received : 21 Jun 2024 300 PORTWELL RD. Lab Number : 06217349 Tested : 25 Jun 2024 HOUSTON, TX

: 25 Jun 2024 - Doug Bogart



To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Diagnosed

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: TYSHOU [WUSCAR] 06217349 (Generated: 06/25/2024 17:52:07) Rev: 1

Certificate 12367

Contact/Location: SERVICE MANAGER - TYSHOU Page 2 of 2

US 77029

T:

F:

Contact: SERVICE MANAGER