




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
ENGINE ROOM
 Machine Id
C-3 (S/N S0839PFMCTHAA03)
 Component
Refrigeration Compressor
 Fluid
USPI 1009-68 SC (85 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USP0013140	USP0008166	USP0005202
Sample Date	Client Info	18 Jun 2024	28 Mar 2024	27 Dec 2023
Machine Age	hrs Client Info	20802	19849	17851
Oil Age	hrs Client Info	20802	3081	17851
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>8	<1	<1	0
Chromium ppm ASTM D5185m	>2	<1	<1	0
Nickel ppm ASTM D5185m		<1	<1	0
Titanium ppm ASTM D5185m		<1	<1	0
Silver ppm ASTM D5185m	>2	<1	0	0
Aluminum ppm ASTM D5185m	>3	0	0	0
Lead ppm ASTM D5185m	>2	<1	<1	0
Copper ppm ASTM D5185m	>8	<1	<1	0
Tin ppm ASTM D5185m	>4	<1	1	0
Vanadium ppm ASTM D5185m		<1	<1	0
Cadmium ppm ASTM D5185m		<1	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m		0	0	0
Barium ppm ASTM D5185m		1	0	0
Molybdenum ppm ASTM D5185m		<1	<1	0
Manganese ppm ASTM D5185m		<1	<1	0
Magnesium ppm ASTM D5185m		<1	<1	0
Calcium ppm ASTM D5185m		0	0	0
Phosphorus ppm ASTM D5185m		<1	0	0
Zinc ppm ASTM D5185m		<1	0	0
Sulfur ppm ASTM D5185m	50	0	0	0

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>15	2	2	<1
Sodium ppm ASTM D5185m		0	0	0
Potassium ppm ASTM D5185m	>20	1	1	0
Water % ASTM D6304	>0.01	0.002	0.003	0.002
ppm Water ppm ASTM D6304	>100	22	38	19

FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm ASTM D7647	>10000	674	7143	622
Particles >6µm ASTM D7647	>2500	196	813	144
Particles >14µm ASTM D7647	>320	9	23	12
Particles >21µm ASTM D7647	>80	2	5	3
Particles >38µm ASTM D7647	>20	0	0	1
Particles >71µm ASTM D7647	>4	0	0	0
Oil Cleanliness ISO 4406 (c)	>20/18/15	17/15/10	20/17/12	16/14/11

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D974	0.005	0.014	0.014	0.014




OIL ANALYSIS REPORT





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	67	65.7	66.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USP0013140
 Lab Number : 06217356
 Unique Number : 11090220
 Test Package : IND 2
 Received : 21 Jun 2024
 Tested : 25 Jun 2024
 Diagnosed : 25 Jun 2024 - Doug Bogart

TYSON - ROCHELLE
 ROCHELLE, IL
 US 61068
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)