



# FUEL REPORT

Sample Rating Trend



**NORMAL**



Machine Id

## KIOTI CK2620H PA3TA1430

Component

**Diesel Fuel**

Fluid

**No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)**

### DIAGNOSIS

#### Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

#### Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

#### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KT0001508</b>	---	---
Sample Date	Client Info			<b>01 Jun 2024</b>	---	---
Machine Age	hrs	Client Info		<b>79</b>	---	---
Sample Status				<b>NORMAL</b>	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		<b>L3.0</b>	---	---
Visc @ 40°C	cSt	ASTM D445	3.0	<b>2.4</b>	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	<b>56.5</b>	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	<b>0</b>	---	---
Sulfur (UVF)	ppm	ASTM D5453		<b>10</b>	---	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	<b>167</b>	---	---
5% Distillation Point	°C	ASTM D86		<b>188</b>	---	---
10% Distill Point	°C	ASTM D86	201	<b>198</b>	---	---
15% Distillation Point	°C	ASTM D86		<b>206</b>	---	---
20% Distill Point	°C	ASTM D86	216	<b>214</b>	---	---
30% Distill Point	°C	ASTM D86	230	<b>229</b>	---	---
40% Distill Point	°C	ASTM D86	243	<b>244</b>	---	---
50% Distill Point	°C	ASTM D86	255	<b>258</b>	---	---
60% Distill Point	°C	ASTM D86	267	<b>274</b>	---	---
70% Distill Point	°C	ASTM D86	280	<b>289</b>	---	---
80% Distill Point	°C	ASTM D86	295	<b>307</b>	---	---
85% Distillation Point	°C	ASTM D86		<b>319</b>	---	---
90% Distill Point	°C	ASTM D86	310	<b>331</b>	---	---
95% Distillation Point	°C	ASTM D86		<b>351</b>	---	---
Final Boiling Point	°C	ASTM D86	341	<b>369</b>	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	<b>37</b>	---	---
Cetane Index		ASTM D4737	<40.0	<b>48</b>	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>&lt;1</b>	---	---
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Potassium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	---	---
Water	%	ASTM D6304	<0.05	<b>0.003</b>	---	---
ppm Water	ppm	ASTM D6304	<500	<b>36</b>	---	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	---	---
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	---	---



# FUEL REPORT






FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	<b>1222</b>	---	---
Particles >6µm	ASTM D7647	>640	<b>486</b>	---	---
Particles >14µm	ASTM D7647	>80	<b>55</b>	---	---
Particles >21µm	ASTM D7647	>20	<b>12</b>	---	---
Particles >38µm	ASTM D7647	>4	<b>0</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>17/16/13</b>	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	<b>&lt;1</b>	---	---
Nickel	ppm	ASTM D5185m <0.1	<b>&lt;1</b>	---	---
Lead	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Iron	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Calcium	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Magnesium	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Phosphorus	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Zinc	ppm	ASTM D5185m <0.1	<b>0</b>	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KT0001508 **Received** : 21 Jun 2024  
**Lab Number** : **06217655** **Tested** : 27 Jun 2024  
**Unique Number** : 11090519 **Diagnosed** : 28 Jun 2024 - Doug Bogart  
**Test Package** : DF-2 ( Additional Tests: Fuel, Screen )

**FIVE 7 EQUIPMENT**  
 1805 E 8TH ST  
 CHANDLER, OK  
 US 74834  
 Contact: JOSH  
 JOSH@FIVE7EQUIPMENT.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)