


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

NVH 3-4 METERING UNIT

Hydraulic System

SHELL TELLUS 46 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TLC0001896		
Sample Date		Client Info		20 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	0		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>20	4		
Tin	ppm	ASTM D5185m	>20	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.0	<1		
Barium	ppm	ASTM D5185m	0	0		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	11	57		
Calcium	ppm	ASTM D5185m	35	42		
Phosphorus	ppm	ASTM D5185m	266	301		
Zinc	ppm	ASTM D5185m	276	335		
Sulfur	ppm	ASTM D5185m	1847	880		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2


Acid Number (AN)

mg KOH/g ASTM D8045 0.36

0.33




OIL ANALYSIS REPORT







GRAPHS













Certificate 12367

Laboratory Sample No.

Lab Number : 06218195

: TLC0001896

Unique Number : 11096392 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 24 Jun 2024

> **Tested** : 25 Jun 2024

Diagnosed

: 25 Jun 2024 - Don Baldridge

AIKEN, SC US 29803 Contact: JEFFREY WASHICK jeffrey.washick@autoneum.com

1103 POWDERHOUSE RD

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: AUTAIK [WUSCAR] 06218195 (Generated: 06/25/2024 19:31:05) Rev: 1

T:

F:

AUTONEUM