




OIL ANALYSIS REPORT

Area
PRESS
 Machine Id
0809CD02
 Component
Gearbox
 Fluid
KLUBER Klübersynth GH 6 ISO 320 (6 LTR)

Sample Rating Trend



WATER



DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0773257	WC0762936	WC0806886
Sample Date	Client Info		17 Apr 2024	24 Jan 2024	18 Jul 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		46	35	44
Iron	ppm	ASTM D5185m >200	4	7	11
Chromium	ppm	ASTM D5185m >15	0	<1	<1
Nickel	ppm	ASTM D5185m >15	<1	0	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	2	1
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >200	0	0	<1
Tin	ppm	ASTM D5185m >25	1	<1	0
Vanadium	ppm	ASTM D5185m	0	<1	<1
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	1	3	10
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	1	<1	2
Calcium	ppm	ASTM D5185m	<1	4	12
Phosphorus	ppm	ASTM D5185m 2450	2347	1964	2408
Zinc	ppm	ASTM D5185m	19	10	73
Sulfur	ppm	ASTM D5185m	0	287	136

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	49	35	▲ 75
Sodium	ppm	ASTM D5185m	0	5	11
Potassium	ppm	ASTM D5185m >20	4	<1	2
Water	%	ASTM D6304 >0.2	▲ 0.915	▲ 0.666	▲ 1.052
ppm Water	ppm	ASTM D6304 >2000	▲ 9159	▲ 6667	▲ 10520.1

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 115030	▲ 151962	▲ 28103
Particles >6µm	ASTM D7647	>640	▲ 17038	▲ 29286	▲ 3819
Particles >14µm	ASTM D7647	>80	▲ 233	▲ 628	▲ 151
Particles >21µm	ASTM D7647	>20	▲ 28	▲ 110	▲ 36
Particles >38µm	ASTM D7647	>4	1	2	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 24/21/15	▲ 24/22/16	▲ 22/19/14

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.955	3.24	3.11	▲ 4.27




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	336.9	334	335

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0773257 **Received** : 24 Jun 2024
Lab Number : 06218238 **Tested** : 25 Jun 2024
Unique Number : 11096435 **Diagnosed** : 26 Jun 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

ARAUCO FLAKEBOARD - MDF
 985 CORINTH RD
 MONCURE, NC
 US
 Contact: JAMES WALTON
 james.walton@arauco.com
 T: (919)642-6696
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)