


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

2279-C-14 SOUTH 500 SULLAIR (S/N 930GLLF)

Refrigeration Compressor

Fluid

USPI 1009-68 SC (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.


Fluid Condition


The TAN level is acceptable for this fluid. The condition of the oil is suitable for further service. Viscosity confirmed.


12011 Oct2012 Feb2016 Nev2017 Aug2019 Aug2020 Occ2021 Mar2023							
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		USP0013114	USP0006136	USP0005002	
Sample Date		Client Info		01 Jun 2024	09 Mar 2024	01 Dec 2023	
Machine Age	hrs	Client Info		0	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				NORMAL	ATTENTION	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>8	0	0	0	
Chromium	ppm	ASTM D5185m	>2	0	0	<1	
Nickel	ppm	ASTM D5185m		0	0	0	
Titanium	ppm	ASTM D5185m		0	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	0	0	
Lead	ppm	ASTM D5185m	>2	0	0	0	
Copper	ppm	ASTM D5185m	>8	0	0	0	
Tin	ppm	ASTM D5185m	>4	0	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	0	
Manganese	ppm	ASTM D5185m		0	<1	0	
Magnesium	ppm	ASTM D5185m		0	0	0	
Calcium	ppm	ASTM D5185m		0	0	0	
Phosphorus	ppm	ASTM D5185m		0	0	0	
Zinc	ppm	ASTM D5185m		<1	0	0	
Sulfur	ppm	ASTM D5185m	50	0	0	0	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	0	0	0	
Sodium	ppm	ASTM D5185m		<1	0	0	
Potassium	ppm	ASTM D5185m	>20	0	0	<1	
Water	%	ASTM D6304	>0.01	0.003	0.003	0.004	
ppm Water	ppm	ASTM D6304	>100	39	34	42	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2	
Particles >4μm		ASTM D7647	>10000	3406	12859	5421	
Particles >6µm		ASTM D7647	>2500	884	2014	1277	
Particles >14µm		ASTM D7647	>320	16	36	42	
Particles >21µm		ASTM D7647	>80	2	7	8	
Particles >38µm		ASTM D7647	>20	1	0	0	
Particles >71μm		ASTM D7647	>4	0	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/11	21/18/12	20/17/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.013	0.014	0.014	





OIL ANALYSIS REPORT











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES method limit/base curre					for the control of	la i a la va e O
FLUID PROPERI	IES	method	limit/base	current	history1	history2

FLUID PROPERTIES		method	ilmit/base		nistory i	nistoryz	
	Visc @ 40°C	cSt	ASTM D445	67	63.9	63.6	63.4

SAMPLE IMAGES

Color

Bottom



GRAPHS Ferrous Alloys Particle Count 150 491.52 122,88 30.72 1,920 Non-ferrous Metals 480 250 120 200 150 Viscosity @ 40°C Acid Number 400 1.50 (mg KOH/g) 300 00.00 PG





Certificate 12367

Laboratory

Sample No. Lab Number : 06218294 Unique Number : 11096491

Test Package : IND 2

: USP0013114

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 24 Jun 2024 **Tested** : 25 Jun 2024

Diagnosed : 25 Jun 2024 - Doug Bogart

SMITHFIELD - DENISON - SMIDENIOW

800 INDUSTRIAL ROAD DENISON, IA US 51442

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: SERVICE MANAGER - FARDEN

T: (712)263-7414 F: (712)263-7314