




FUEL REPORT

Sample Rating Trend



NORMAL



Area

JE A JACKSONVILLE FL [11929]

Machine Id

[JE A JACKSONVILLE FL] GEN-0557

Component

Diesel Fuel

Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (500 GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0957721	---	---
Sample Date	Client Info	23 Jun 2024	---	---
Machine Age	hrs Client Info	0	---	---
Sample Status		NORMAL	---	---

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
Fuel Color	text *Visual Screen	Yellow	Red	---
ASTM Color	scalar *ASTM D1500		L4.0	---
Visc @ 40°C	cSt ASTM D445	3.0	2.43	---
Pensky-Martens Flash Point	°C *PMCC Calculated	52	64.3	---

SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm ASTM D5185m	10	3	---
Sulfur (UVF)	ppm ASTM D5453		11	---

DISTILLATION

method	limit/base	current	history1	history2
Initial Boiling Point	°C ASTM D86	165	176	---
5% Distillation Point	°C ASTM D86		197	---
10% Distill Point	°C ASTM D86	201	205	---
15% Distillation Point	°C ASTM D86		212	---
20% Distill Point	°C ASTM D86	216	220	---
30% Distill Point	°C ASTM D86	230	233	---
40% Distill Point	°C ASTM D86	243	246	---
50% Distill Point	°C ASTM D86	255	259	---
60% Distill Point	°C ASTM D86	267	273	---
70% Distill Point	°C ASTM D86	280	287	---
80% Distill Point	°C ASTM D86	295	303	---
85% Distillation Point	°C ASTM D86		314	---
90% Distill Point	°C ASTM D86	310	325	---
95% Distillation Point	°C ASTM D86		343	---
Final Boiling Point	°C ASTM D86	341	358	---

IGNITION QUALITY






method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.7	36	---
Cetane Index	ASTM D4737	<40.0	48	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m	<1.0	<1	---
Sodium	ppm ASTM D5185m	<0.1	2	---
Potassium	ppm ASTM D5185m	<0.1	1	---
Water	% ASTM D6304	<0.05	0.005	---
ppm Water	ppm ASTM D6304	<500	59	---
% Gasoline	% *In-House	<0.50	0.0	---
% Biodiesel	% *In-House	<20.0	0.0	---



FUEL REPORT






FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	119	---	---
Particles >6µm	ASTM D7647	>640	37	---	---
Particles >14µm	ASTM D7647	>80	4	---	---
Particles >21µm	ASTM D7647	>20	0	---	---
Particles >38µm	ASTM D7647	>4	0	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	14/12/9	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	---	---
Nickel	ppm	ASTM D5185m <0.1	0	---	---
Lead	ppm	ASTM D5185m <0.1	0	---	---
Vanadium	ppm	ASTM D5185m <0.1	0	---	---
Iron	ppm	ASTM D5185m <0.1	0	---	---
Calcium	ppm	ASTM D5185m <0.1	0	---	---
Magnesium	ppm	ASTM D5185m <0.1	0	---	---
Phosphorus	ppm	ASTM D5185m <0.1	0	---	---
Zinc	ppm	ASTM D5185m <0.1	0	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0957721 **Received** : 24 Jun 2024
Lab Number : **06218712** **Tested** : 26 Jun 2024
Unique Number : 11096909 **Diagnosed** : 26 Jun 2024 - Elizabeth Valachovic
Test Package : DF-2 (Additional Tests: Fuel, Screen)

PETROLEUM RECOVERY SERVICES
 210 POWELL DR
 SUMMERVILLE, SC
 US 29483
 Contact: AJAY EL
 Ajay@prsfuel.com
 T: (843)225-1777
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)