


FUEL REPORT

Lewis Gale Hospital Montgomery [17532] [Lewis Gale Hospital Montgomery] MAIN

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (8000 GAL)





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

) (8000 GAL)			Mar2024	Jun 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0957807	WC06139455	
Sample Date		Client Info		23 Jun 2024	21 Mar 2024	
Machine Age	hrs	Client Info		0	0	
Sample Status				NORMAL	ABNORMAL	
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red	Red	
ASTM Color	scalar	*ASTM D1500		L4.0	L4.5	
Visc @ 40°C	cSt	ASTM D445	3.0	2.49	2.53	
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	62.2	62.7	
SULFUR CONTER	NΤ	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	528	500	
Sulfur (UVF)	ppm	ASTM D5453		218	419	
DISTILLATION		method	limit/base	current	history1	history2
nitial Boiling Point	°C	ASTM D86	165	173	174	
5% Distillation Point	°C	ASTM D86		196	197	
0% Distill Point	°C	ASTM D86	201	206	207	
5% Distillation Point	°C	ASTM D86		214	215	
20% Distill Point	°C	ASTM D86	216	222	223	
30% Distill Point	°C	ASTM D86	230	236	237	
10% Distill Point	°C	ASTM D86	243	249	250	
50% Distill Point	°C	ASTM D86	255	262	263	
60% Distill Point	°C	ASTM D86	267	275	276	
70% Distill Point	°C	ASTM D86	280	288	289	
30% Distill Point	°C	ASTM D86	295	303	304	
35% Distillation Point	°C	ASTM D86		314	315	
90% Distill Point	°C	ASTM D86	310	325	325	
95% Distillation Point	°C	ASTM D86		343	343	
Final Boiling Point	°C	ASTM D86	341	357	358	
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36	36	
Cetane Index		ASTM D4737	<40.0	46	47	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	
Sodium	ppm	ASTM D5185m	<0.1	2	<1	
Potassium	ppm	ASTM D5185m	<0.1	<1	0	
Water	%	ASTM D6304	< 0.05	0.006	0.004	
opm Water	ppm	ASTM D6304	< 500	67	49	
% Gasoline	%	*In-House	< 0.50	0.0	0.0	
% Biodiesel	%	*In-House	<20.0	0.0	0.0	



FUEL REPORT







Sample No.

: WC0957807 Lab Number : 06218720

Unique Number : 11096917

Received : 24 Jun 2024 **Tested** Diagnosed

: 27 Jun 2024 : 27 Jun 2024 - Elizabeth Valachovic

SUMMERVILLE, SC US 29483 Contact: AJAY EL Ajay@prsfuel.com T: (843)225-1777

210 POWELL DR

Test Package : DF-2 (Additional Tests: Fuel, Screen) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: PETSUM [WUSCAR] 06218720 (Generated: 06/29/2024 19:25:23) Rev: 1

Contact/Location: AJAY EL - PETSUM