


FUEL REPORT

VA MEDICAL CENTER MARION IL [17893] [VA MEDICAL CENTER MARION IL] TANK 2

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

R) (8000 GAL)			,	Jun2024		
SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0957793		
Sample Date		Client Info		23 Jun 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L5.0		
Visc @ 40°C	cSt	ASTM D445	3.0	2.57		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	63.2		
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	848		
Sulfur (UVF)	ppm	ASTM D5453		639		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	174		
5% Distillation Point	°C	ASTM D86		199		
10% Distill Point	°C	ASTM D86	201	210		
15% Distillation Point	°C	ASTM D86		218		
20% Distill Point	°C	ASTM D86	216	226		
30% Distill Point	°C	ASTM D86	230	240		
40% Distill Point	°C	ASTM D86	243	253		
50% Distill Point	°C	ASTM D86	255	266		
60% Distill Point	°C	ASTM D86	267	278		
70% Distill Point	°C	ASTM D86	280	291		
80% Distill Point	°C	ASTM D86	295	305		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86	310	324		
95% Distillation Point	°C	ASTM D86		340		
Final Boiling Point	°C	ASTM D86	341	354		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	35		
Cetane Index		ASTM D4737	<40.0	45		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	< 0.1	1		
Potassium	ppm	ASTM D5185m	< 0.1	1		
Water	%	ASTM D6304	< 0.05	0.004		
ppm Water	ppm	ASTM D6304	< 500	47		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT







Certificate 12367

Sample No.

: WC0957793 Lab Number : 06218727

Unique Number : 11096924

Diagnosed Test Package : DF-2 (Additional Tests: Fuel, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Tested

: 27 Jun 2024

: 27 Jun 2024 - Elizabeth Valachovic

US 29483

SUMMERVILLE, SC

Contact: AJAY EL

Ajay@prsfuel.com

T: (843)225-1777