




# OIL ANALYSIS REPORT

## Sample Rating Trend



Machine Id  
**GOULDS N209H758-1**  
 Component  
**Pump Hydraulic System**  
 Fluid  
**ROYAL PURPLE SYNFILM 68 (--- LTR)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### Wear

The copper level is abnormal. All other component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The oil viscosity is higher than normal. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>RP0032040</b>	RP0031852	---
Sample Date	Client Info	<b>15 May 2024</b>	16 Nov 2023	---
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	---
Sample Status		<b>ABNORMAL</b>	NORMAL	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>7</b>	9
Chromium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0
Nickel	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0
Silver	ppm	ASTM D5185m	<b>&lt;1</b>	0
Aluminum	ppm	ASTM D5185m >20	<b>3</b>	1
Lead	ppm	ASTM D5185m >20	<b>1</b>	0
Copper	ppm	ASTM D5185m >20	<b>▲ 25</b>	13
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	2
Barium	ppm	ASTM D5185m	<b>1</b>	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0
Manganese	ppm	ASTM D5185m	<b>1</b>	<1
Magnesium	ppm	ASTM D5185m 90	<b>● 12</b>	29
Calcium	ppm	ASTM D5185m	<b>● 100</b>	25
Phosphorus	ppm	ASTM D5185m	<b>● 129</b>	91
Zinc	ppm	ASTM D5185m	<b>● 41</b>	0

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>3</b>	17
Sodium	ppm	ASTM D5185m	<b>0</b>	2
Potassium	ppm	ASTM D5185m >20	<b>2</b>	1
Water	%	ASTM D6304 >0.05	<b>0.006</b>	0.001
ppm Water	ppm	ASTM D6304 >500	<b>63</b>	14






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>▲ 28092</b>	---	---
Particles >6µm	ASTM D7647 >1300	<b>▲ 6432</b>	---	---
Particles >14µm	ASTM D7647 >160	<b>▲ 336</b>	---	---
Particles >21µm	ASTM D7647 >40	<b>▲ 58</b>	---	---
Particles >38µm	ASTM D7647 >10	<b>1</b>	---	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>▲ 22/20/16</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.25	<b>0.25</b>	0.27


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 68	523	339	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0032040  
**Lab Number** : 06218755  
**Unique Number** : 11096952  
**Test Package** : IND 2  
**Received** : 24 Jun 2024  
**Tested** : 25 Jun 2024  
**Diagnosed** : 26 Jun 2024 - Don Baldrige

**JEFFERSON ENERGY CO**  
 94 OLD HWY 90  
 VIDOR, TX  
 US 77662  
 Contact: KEITH JENKINS

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)