


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

6221594 (S/N 1081) Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

				Jun 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012282		
Sample Date		Client Info		19 Jun 2024		
Machine Age	hrs	Client Info		31996		
Oil Age	hrs	Client Info		8000		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	9		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m	>10	<u> 12</u>		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm		>50	3		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m	710	<1		
Cadmium	ppm	ASTM D5185m		<1		
	ррпп			\ 1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	2		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	100	3		
Calcium	ppm	ASTM D5185m	0	0		
Phosphorus	ppm	ASTM D5185m	0	123		
Zinc	ppm	ASTM D5185m	0	5		
Sulfur	ppm	ASTM D5185m	23500	3104		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	2		
Water	%	ASTM D6304	>0.05	0.014		
ppm Water	ppm	ASTM D6304	>500	148		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		70579		
Particles >6µm		ASTM D7647	>1300	6901		
Particles >14µm		ASTM D7647	>80	186		
Particles >21µm		ASTM D7647	>20	<u>^</u> 26		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	23/20/15		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.43		



OIL ANALYSIS REPORT





Laboratory Sample No.

Lab Number

: KCPA012282 : 06218761 Unique Number : 11096958

Received : 24 Jun 2024 **Tested**

: 27 Jun 2024 Diagnosed

: 27 Jun 2024 - Jonathan Hester

US 28392 Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

16261 NC 87

TARHEEL, NC

F: (910)862-5276