


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

## **KAESER 8105133**

Component Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			May2023	Jun2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017608	KCPA001628	
Sample Date		Client Info		12 Jun 2024	16 May 2023	
Machine Age	hrs	Client Info		2306	1070	
Oil Age	hrs	Client Info		2306	0	
Oil Changed	0	Client Info		Changed	N/A	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	<1	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	3	0	
Lead	ppm	ASTM D5185m	>10	<1	<1	
Copper	ppm	ASTM D5185m		4	2	
Tin	ppm	ASTM D5185m	>10	- <1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES	1-1-	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	1	14	
Molybdenum	ppm	ASTM D5185m	0	- <1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	44	74	
Calcium	ppm	ASTM D5185m	0	0	<1	
Phosphorus	ppm	ASTM D5185m	0	7	3	
Zinc	ppm	ASTM D5185m	0	6	7	
Sulfur	ppm	ASTM D5185m	23500	19527	22889	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	
Sodium	ppm	ASTM D5185m	720	11	10	
Potassium	ppm	ASTM D5185m	>20	17	18	
Water	%	ASTM D6304	>0.05	0.021	△ 0.058	
ppm Water	ppm	ASTM D6304	>500	212	▲ 581.7	
FLUID CLEANLIN	ESS _	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2554	2294	
Particles >6µm		ASTM D7647	>1300	866	642	
Particles >14µm		ASTM D7647	>80	42	16	
Particles >21µm		ASTM D7647	>20	8	3	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	18/17/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.36	0.36	



## OIL ANALYSIS REPORT







Certificate 12367

Sample No.

Laboratory Lab Number

: KCPA017608 : 06218772 Unique Number : 11096969

Received **Tested** 

Diagnosed : 26 Jun 2024 - Jonathan Hester

: 24 Jun 2024

: 25 Jun 2024

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

**FANATICS DISTRIBUTION** 727 OLD PHILADELPHIA RD

ABERDEEN, MD US 21001 Contact: T LOCASH

TLOCASH@FANATICS.COM T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: