


OIL ANALYSIS REPORT



Machine Id

KAESER 9428325 (S/N 1002)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jun2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018597		
Sample Date		Client Info		14 Jun 2024		
Machine Age	hrs	Client Info		3569		
Oil Age	hrs	Client Info		3600		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	9		
Chromium	ppm		>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m		<u> </u>		
Lead		ASTM D5185m	>10	<1		
	ppm	ASTM D5185m		14		
Copper Tin	ppm					
Vanadium	ppm	ASTM D5185m	>10	<1 <1		
	ppm	ASTM D5185m				
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	1		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	6		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		1		
Zinc	ppm	ASTM D5185m		21		
Sulfur	ppm	ASTM D5185m		19690		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	7		
Water	%	ASTM D6304	>0.05	0.009		
ppm Water	ppm	ASTM D6304	>500	94		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		15892		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	▲ 732		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	2		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	△ 21/20/17		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.40		



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number

: KCPA018597 : 06218781 Unique Number : 11096978

Received : 24 Jun 2024 **Tested** : 26 Jun 2024 Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 26 Jun 2024 - Jonathan Hester

Contact: Service Manager

242 PERDUE RD

COFIELD, NC

US 27922

T:

F:

Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: PERCOFNC [WUSCAR] 06218781 (Generated: 06/27/2024 13:25:45) Rev: 1

Contact/Location: Service Manager - PERCOFNC