


OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id

KAESER SM 10 4449147 (S/N 1289)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec2014	May2016 Jan2018	May2019 Mar2021 Ja	n2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA019421	KCPA008858	KCP36294
Sample Date		Client Info		18 Jun 2024	11 Jan 2024	04 Oct 2021
Machine Age	hrs	Client Info		55107	52929	39730
Oil Age	hrs	Client Info		2278	0	6989
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ATTENTION	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	3	1	2
Lead	ppm	ASTM D5185m	>10	<1	0	<1
Copper	ppm	ASTM D5185m	>50	17	14	18
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	2	15	14
Calcium	ppm	ASTM D5185m	2	0	<1	0
Phosphorus	ppm	ASTM D5185m		3	11	2
Zinc	ppm	ASTM D5185m		17	4	38
Sulfur	ppm	ASTM D5185m		18400	18244	16524
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		0	4	4
Potassium	ppm	ASTM D5185m	>20	2	1	3
Water	%	ASTM D6304	>0.05	0.006	0.006	0.011
ppm Water	ppm	ASTM D6304	>500	64	60	116.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		6076	4254	1970
Particles >6µm		ASTM D7647	>1300	1622	1105	470
Particles >14µm		ASTM D7647	>80	92	92	39
Particles >21µm		ASTM D7647	>20	19	28	10
Particles >38µm		ASTM D7647	>4	1	1	1
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/14	19/17/14	16/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT






I LOID I HOI LITTILO							
Visc @ 40°C	cSt	ASTM D445	46	43.8	43.91	44.4	


SAMPLE IMAGES


Color


Bottom















Certificate 12367

Laboratory Sample No.

Lab Number : 06218782 Unique Number : 11096979

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA019421

Received : 24 Jun 2024 **Tested** : 26 Jun 2024 Diagnosed

: 26 Jun 2024 - Jonathan Hester

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

OLD DOMINION FREIGHTLINERS

3608 ROOY MESSER HWY WHITE PINO, TN US 37890

Contact: KEVIN SHULL kevin.shull@odfl.com

T:

F: