




OIL ANALYSIS REPORT

Sample Rating Trend



VIS DEBRIS



Machine Id
KAESER CSD 125 6914011 (S/N 1007)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCPA019422	KCP54208	KC104938
Sample Date	Client Info			14 Jun 2024	05 May 2023	03 Aug 2022
Machine Age	hrs	Client Info		16950	11221	7368
Oil Age	hrs	Client Info		3000	3853	4719
Oil Changed	Client Info			N/A	Not Changd	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	3
Chromium	ppm	ASTM D5185m	>10	<1	<1	0
Nickel	ppm	ASTM D5185m	>3	<1	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	3	0	0
Lead	ppm	ASTM D5185m	>10	<1	1	0
Copper	ppm	ASTM D5185m	>50	8	7	12
Tin	ppm	ASTM D5185m	>10	4	6	2
Antimony	ppm	ASTM D5185m		---	---	---
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	<1	0




ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	0
Manganese	ppm	ASTM D5185m		2	2	4
Magnesium	ppm	ASTM D5185m	90	22	40	19
Calcium	ppm	ASTM D5185m	2	0	0	45
Phosphorus	ppm	ASTM D5185m		<1	<1	14
Zinc	ppm	ASTM D5185m		10	0	33
Sulfur	ppm	ASTM D5185m		19422	21204	17594

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	3
Sodium	ppm	ASTM D5185m		5	15	8
Potassium	ppm	ASTM D5185m	>20	3	6	3
Water	%	ASTM D6304	>0.05	0.011	0.016	0.013
ppm Water	ppm	ASTM D6304	>500	114	164.8	132.5

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		---	942	52003
Particles >6µm		ASTM D7647	>1300	---	344	▲ 5706
Particles >14µm		ASTM D7647	>80	---	41	38
Particles >21µm		ASTM D7647	>20	---	12	2
Particles >38µm		ASTM D7647	>4	---	1	0
Particles >71µm		ASTM D7647	>3	---	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	---	17/16/13	▲ 23/20/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.41	0.36	0.34


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	45.2	44.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : KCPA019422

Lab Number : 06218791

Unique Number : 11096988

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 24 Jun 2024

Tested : 26 Jun 2024

Diagnosed : 26 Jun 2024 - Jonathan Hester

JOHNSON CONTROLS - ADIENT CLANTON INC

2541 7TH ST S

CLANTON, AL

US 35046

Contact: JONATHON PAYNE

jonathon.d.payne@adient.com

T:

F: