


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

2081472 (S/N 1599)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ju	2022	Jun2023 Jun202	24	
SAMPLE INFORM	MATION	method	limit/base	our wordt	history	history
	TATION		imivoase	current	history1	history2
Sample Number		Client Info		KCPA018580	KCP34632	KCP40187
Sample Date		Client Info		17 Jun 2024	27 Jun 2023	22 Jun 2022
Machine Age	hrs	Client Info		26372	20740	14038
Oil Age	hrs	Client Info		3000	6702	8770
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	3	0	<1
Lead	ppm	ASTM D5185m	>10	<1	0	<1
Copper	ppm	ASTM D5185m	>50	5	9	11
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	2	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	24	<1	2
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		2	0	10
Zinc	ppm	ASTM D5185m		59	18	11
Sulfur	ppm	ASTM D5185m		20065	17011	19541
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		9	0	0
Potassium	ppm	ASTM D5185m	>20	4	<1	1
Water	%	ASTM D6304	>0.05	0.012	0.008	0.010
ppm Water	ppm	ASTM D6304	>500	126	83.6	104.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2783	1074	7480
Particles >6µm		ASTM D7647	>1300	685	284	2208
Particles >14µm		ASTM D7647	>80	45	37	▲ 178
Particles >21µm		ASTM D7647	>20	11	11	3 1
Particles >38µm		ASTM D7647	>4	0	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	17/15/12	2 0/18/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.40	0.45



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

: KCPA018580 : 06218804

Unique Number : 11097001

Received

Tested : 26 Jun 2024 Diagnosed : 26 Jun 2024 - Doug Bogart

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: 24 Jun 2024

T: F:

255 N UNION ST

US 14605

ROCHESTER, NY

Contact: Service Manager