




PROBLEM SUMMARY

Sample Rating Trend







DEGRADATION



Machine Id
ATLAS COPCO TYSGOO 3 (S/N APF172836)
 Component
Air Compressor
 Fluid
USPI FG AIR 46 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status		SEVERE	NORMAL	NORMAL
Acid Number (AN)	mg KOH/g	▲ 14.05	0.71	0.55
Visc @ 40°C	cSt	▲ 72.8	43.4	43.0

Customer Id: TYSGOO
 Sample No.: USP246524
 Lab Number: 06218807
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.
Flush System	---	---	?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

NORMAL




25 Apr 2024 Diag: Jonathan Hester

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



16 Jan 2024 Diag: Doug Bogart

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



08 Oct 2023 Diag: Jonathan Hester

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id
ATLAS COPCO TYSGOO 3 (S/N APF172836)
 Component
Air Compressor
 Fluid
USPI FG AIR 46 (--- GAL)

DIAGNOSIS

▲ Recommendation

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

● Wear

An increase in the copper and zinc levels is noted.

Contamination

There is no indication of any contamination in the oil.

▲ Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. Confirmed.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP246524	USPM19592	USPM26406
Sample Date	Client Info		23 Jun 2024	25 Apr 2024	16 Jan 2024
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >70	3	10	0
Chromium	ppm	ASTM D5185m >15	<1	0	0
Nickel	ppm	ASTM D5185m >6	<1	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >10	3	0	<1
Lead	ppm	ASTM D5185m >20	1	0	0
Copper	ppm	ASTM D5185m >80	32	2	3
Tin	ppm	ASTM D5185m >15	<1	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<1	0	0
Barium	ppm	ASTM D5185m 0	1	0	0
Molybdenum	ppm	ASTM D5185m 0	<1	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m 0	4	0	<1
Calcium	ppm	ASTM D5185m 0	0	0	1
Phosphorus	ppm	ASTM D5185m 0	47	0	<1
Zinc	ppm	ASTM D5185m 0	191	10	0
Sulfur	ppm	ASTM D5185m 0	0	0	9

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >12	1	<1	0
Sodium	ppm	ASTM D5185m	9	0	0
Potassium	ppm	ASTM D5185m >20	4	0	0
Water	%	ASTM D6304 >0.1	0.087	0.021	0.007
ppm Water	ppm	ASTM D6304 >1000	874	214	73

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	2073	422	329
Particles >6µm	ASTM D7647	>2500	484	82	112
Particles >14µm	ASTM D7647	>320	39	8	21
Particles >21µm	ASTM D7647	>80	13	2	6
Particles >38µm	ASTM D7647	>20	1	0	1
Particles >71µm	ASTM D7647	>4	1	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	18/16/12	16/14/10	16/14/12

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.15	▲ 14.05	0.71	0.55




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.8 ▲ 72.8	43.4	43.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP246524 **Received** : 24 Jun 2024
Lab Number : 06218807 **Tested** : 26 Jun 2024
Unique Number : 11097004 **Diagnosed** : 26 Jun 2024 - Doug Bogart
Test Package : IND 2

TYSON -GOODLETTSVILLE-USP
 201 CARTWRIGHT STREET
 GOODLETTSVILLE, TN
 US 37072
 Contact: JOHN BAKER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (615)855-2791
F: (615)855-2742