


## **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SFC 55 6347533 (S/N 1122)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

#### **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Oct2018 Ja	u2019 Jan2020 Apr	2021 Apr2022 May2022	Jul2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC06219667	KC108388	KC104752
Sample Date		Client Info		03 Jun 2024	12 Jul 2023	27 Oct 2022
Machine Age	hrs	Client Info		42836	35890	30884
Oil Age	hrs	Client Info		0	35890	4041
Oil Changed		Client Info		N/A	Changed	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	8	19
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	<1	4	18
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	6	4
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		6	5	50
Potassium	ppm	ASTM D5185m	>20	1	2	8
Water	%	ASTM D6304	>0.05	0.005	0.007	0.026
ppm Water	ppm	ASTM D6304	>500	53	79.8	269.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		8760	9163	88534
Particles >6µm		ASTM D7647		<u>4531</u>	<u>▲</u> 3753	<u>27354</u>
Particles >14μm		ASTM D7647	>80	<u>^</u> 690	<u>451</u>	<u> </u>
Particles >21μm		ASTM D7647		<u> </u>	<u>▲</u> 128	<u></u> 368
Particles >38μm		ASTM D7647	>4	4	3	<u> 11</u>
Particles >71μm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>20/19/17</u>	<u>\$\text{\Delta}\$ 20/19/16</u>	<u>4</u> 24/22/18
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.30	0.33	0.26





## OIL ANALYSIS REPORT





















Certificate 12367

Laboratory Sample No.

Test Package : IND 2

Lab Number : 06219667 Unique Number : 11097864

: KC06219667

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 25 Jun 2024

**Tested** : 26 Jun 2024 Diagnosed

: 26 Jun 2024 - Don Baldridge

1101 E 33RD ST HIALEAH, FL US 33013

SCHWARZ PARTNERS PACKAGING

Contact: W. MONEGRO wmonegro@sppmia.com T:

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: