

OIL ANALYSIS REPORT

Sample Rating Trend

i lee

NORMAL

Machine Id

KAESER DSD 150 4159874 (S/N 1098)

Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- QTS)

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129881	KC126776	KC05982402
Sample Date		Client Info		17 Jun 2024	17 Jan 2024	09 Oct 2023
Machine Age	hrs	Client Info		57607	56992	56230
Oil Age	hrs	Client Info		800	0	0
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				NORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	0	4	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	15	36	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	57	76	57
Calcium	ppm	ASTM D5185m	2	<1	0	0
Phosphorus	ppm	ASTM D5185m		0	0	<1
Zinc	ppm	ASTM D5185m		5	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		16	18	14
Potassium	ppm	ASTM D5185m	>20	2	1	1
Water	%	ASTM D6304	>0.05	0.027	0.013	0.023
ppm Water	ppm	ASTM D6304	>500	274	134	239.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		675	6101	1759
Particles >6µm		ASTM D7647	>1300	173	<u> </u>	610
Particles >14µm		ASTM D7647	>80	16	98	78
Particles >21µm		ASTM D7647	>20	5	29	28
Particles >38µm		ASTM D7647	>4	1	1	3
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/11	20/18/14	18/16/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.44	0.37	0.36





OIL ANALYSIS REPORT














Bottom





Lab Number : 06219673 Tested : 26 Jun 2024 Unique Number : 11097870 Diagnosed : 26 Jun 2024 - Don Baldridge Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Certificate 12367

Contact/Location: SERVICE MANAGER - PERHOU

US 15342

Contact: SERVICE MANAGER