

OIL ANALYSIS REPORT

Sample Rating Trend


VISCOSITY

Machine Id

KAESER ASD 40 6500034 (S/N 1011)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)





DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

CAMPLE INFORM	AATIONI	and the second	11		late to mod	la la tarra O
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018446	KCPA005343	KCP51313
Sample Date		Client Info		07 Jun 2024	22 Jun 2023	07 Jun 2022
Machine Age	hrs	Client Info		16995	14074	11024
Oil Age	hrs	Client Info		0	7071	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	<1	<1
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	2
Copper	ppm	ASTM D5185m	>50	10	8	2
Tin	ppm	ASTM D5185m	>10	0	0	1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	2	19	12
Calcium	ppm	ASTM D5185m	0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	0	3	3
Zinc	ppm	ASTM D5185m	0	0	21	4
Sulfur	ppm	ASTM D5185m	23500	23380	23142	2709
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	1
Sodium	ppm	ASTM D5185m		3	10	16
Potassium	ppm	ASTM D5185m	>20	0	2	31
Water	%	ASTM D6304	>0.05	800.0	0.011	0.021
ppm Water	ppm	ASTM D6304	>500	84	117.4	217.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		24655	3451	7631
Particles >6µm		ASTM D7647	>1300	<u> </u>	736	1599
Particles >14μm		ASTM D7647	>80	<u>▲</u> 579	24	94
Particles >21µm		ASTM D7647	>20	<u>▲</u> 59	3	15
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/20/16</u>	19/17/12	0 20/18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: KCPA018446 Lab Number : 06219691 Unique Number: 11097888

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 25 Jun 2024 **Tested** : 26 Jun 2024

Diagnosed : 26 Jun 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

3366 E WILLOW ST

Contact: Service Manager

SIGNAL HILL, CA

US 90755

T:

F: