


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER 8395991

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			May2023	May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC107785	KC104066	
Sample Date		Client Info		15 May 2024	23 May 2023	
Machine Age	hrs	Client Info		2854	1259	
Oil Age	hrs	Client Info		2854	1259	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	3	3	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	3	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	23	67	
Calcium	ppm	ASTM D5185m	2	0	2	
Phosphorus	ppm	ASTM D5185m		0	1	
Zinc	ppm	ASTM D5185m		0	9	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		7	14	
Potassium	ppm	ASTM D5185m	>20	<1	2	
Water	%	ASTM D6304	>0.05	0.013	0.016	
ppm Water	ppm	ASTM D6304	>500	140	161.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1499	18040	
Particles >6µm		ASTM D7647		536	<u>▲</u> 9147	
Particles >14µm		ASTM D7647	>80	23	<u>^</u> 214	
Particles >21µm		ASTM D7647		4	10	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647		0	0	
Oil Cleanliness	TIGAT	ISO 4406 (c)	>/17/13	18/16/12	<u>21/20/15</u>	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33	0.35	



OIL ANALYSIS REPORT







Certificate 12367

Sample No.

Laboratory : KC107785 Lab Number : 06219697 Unique Number : 11097894 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 25 Jun 2024 **Tested** : 26 Jun 2024 Diagnosed

: 26 Jun 2024 - Don Baldridge

US 19607 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T:

F:

3 COMMERCE DR

FLYING HILLS, PA