

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER ESD 300 8764892 (S/N 1162)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Aug2023	Jun2024		
			Augenes	JUILLOET		
SAMPLE INFORM	//ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129164	KC124255	
Sample Date		Client Info		17 Jun 2024	30 Aug 2023	
Machine Age	hrs	Client Info		4594	1505	
Oil Age	hrs	Client Info		3089	0	
Oil Changed		Client Info		Not Changd	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	3	0	
Copper	ppm	ASTM D5185m	>50	4	3	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m	- 10	0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES	la la		limit/base	current		history2
		method	iiiiii/base		history1	
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	24	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	45	31	
Calcium	ppm	ASTM D5185m	2	<1	0	
Phosphorus	ppm	ASTM D5185m		0	3	
Zinc	ppm	ASTM D5185m		0	0	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		12	10	
Potassium	ppm	ASTM D5185m	>20	4	10	
Water	%	ASTM D6304	>0.05	0.021	0.019	
ppm Water	ppm	ASTM D6304	>500	215	190.3	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3003	406	
Particles >6µm		ASTM D7647	>1300	1191	61	
Particles >14µm		ASTM D7647	>80	74	5	
Particles >21µm		ASTM D7647	>20	13	2	
Particles >38µm		ASTM D7647	>4	1	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	16/13/10	
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
A 1111 1 (AN)	1/011/	40714 00045				

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.36

0.43



OIL ANALYSIS REPORT





Certificate 12367

Sample No. : KC129164 Lab Number : 06219731 Unique Number : 11097928

Test Package : IND 2

Received : 25 Jun 2024 **Tested** : 26 Jun 2024 Diagnosed

: 26 Jun 2024 - Don Baldridge

1355 EASTON RD BETHLEHEM, PA US 18015

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: