


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 5603490 - ROCHLING AUTOMOTIVE (S/N 1120)

Compressor

KAESER SIGMA (OEM) S-460 (8 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0942971	WC0915263	WC0845135
Sample Date		Client Info		19 Jun 2024	27 Mar 2024	28 Sep 2023
Machine Age	hrs	Client Info		48853	48852	0
Oil Age	hrs	Client Info		48853	2	0
Oil Changed		Client Info		N/A	Not Changd	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	<1	1	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	1	<1
Lead	ppm	ASTM D5185m	>10	0	1	0
Copper	ppm	ASTM D5185m	>50	3	2	4
Tin	ppm	ASTM D5185m	>10	0	1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	37	57	<1
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	70	61	32
Calcium	ppm	ASTM D5185m	2	0	5	2
Phosphorus	ppm	ASTM D5185m		0	21	3
Zinc	ppm	ASTM D5185m		4	5	19
Sulfur	ppm	ASTM D5185m		22321	20468	16569
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		11	6	16
Potassium	ppm	ASTM D5185m	>20	3	2	3
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
	140111	4 O T 1 4 D 0 0 : -	0.4			

0.37

0.39


Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.32



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.5	44.4	43.5
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						

GRAPHS Ferrous Alloys Non-ferrous Metals Viscosity @ 40°C Acid Number (B) 0.60 W 0.48 Ĕ0.36 0.24 0.12 0.00 PG





Certificate 12367

Laboratory Sample No.

Lab Number : 06219836 Unique Number : 11098033

: WC0942971

Bottom

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

Jun14/23

: 25 Jun 2024 **Tested** : 26 Jun 2024 Diagnosed : 26 Jun 2024 - Sean Felton

Mar27/24

ELEVATED INDUSTRIAL SOLUTIONS - EIS 302 HUGHES ST FOUNTAIN INN, SC US 29644

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: DARRIN WARD dward@elevatedindustrial.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: DARRIN WARD

F: (864)862-7653

T: