


# **FUEL REPORT**

# **GRAND STRAND REGIONAL MEDICAL CENTER [17818]** [GRAND STRAND REGIONAL MEDICAL CENTER] MAIN 1 GEN

**Diesel Fuel** 

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (15000 GAL)





# **DIAGNOSIS**

#### Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system. There is too contamination present in this sample to perform a particle count.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

Though microbial test was negative, appearance indicates possible Bacteria, Yeast and/or Fungus present in the sample. Excessive free water present. There is a high amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the fuel.


### **Fuel Condition**

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

R) (15000 GAL)				Jun 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0957812		
Sample Date		Client Info		25 Jun 2024		
Machine Age	hrs	Client Info		0		
Sample Status				SEVERE		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
					· ·	Ť
Fuel Color ASTM Color	text scalar	*Visual Screen *ASTM D1500	Yllow	Red L4.5		
Visc @ 40°C	cSt	ASTM D1300	3.0	2.43		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	59.7		
,						
SULFUR CONTE	NΤ	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		11		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	170		
5% Distillation Point	°C	ASTM D86		193		
10% Distill Point	°C	ASTM D86	201	203		
15% Distillation Point	°C	ASTM D86		212		
20% Distill Point	°C	ASTM D86	216	220		
30% Distill Point	°C	ASTM D86	230	235		
40% Distill Point	°C	ASTM D86	243	249		
50% Distill Point	°C	ASTM D86	255	263		
60% Distill Point	°C	ASTM D86	267	276		
70% Distill Point	°C	ASTM D86	280	290		
80% Distill Point	°C	ASTM D86	295	305		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86	310	325		
95% Distillation Point	°C	ASTM D86		341		
Final Boiling Point	°C	ASTM D86	341	355		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	37		
Cetane Index		ASTM D4737	<40.0	49		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	<1		
Water	%	ASTM D6304	< 0.05	0.006		
ppm Water	ppm	ASTM D6304	<500	62		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	1.1		
MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	0		
Yeast	CFU/ml	WC-Method	>=100000	0		
Mold	Colonies	WC-Method	MODER			



# **FUEL REPORT**







Certificate 12367

Laboratory Sample No.

: WC0957812 Lab Number : 06220304 Unique Number : 11098501

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Tested Diagnosed

: 25 Jun 2024 : 02 Jul 2024 : 02 Jul 2024 - Doug Bogart

Test Package: DF-2 (Additional Tests: Bacteria, Fuel, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.  $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. PETROLEUM RECOVERY SERVICES

210 POWELL DR SUMMERVILLE, SC US 29483

Contact: AJAY EL Ajay@prsfuel.com T: (843)225-1777

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: PETSUM [WUSCAR] 06220304 (Generated: 07/02/2024 23:57:57) Rev: 1

Contact/Location: AJAY EL - PETSUM