



OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
ROCK HILL SCHOOL DISTRICT 3 [18417]
 Machine Id
[ROCK HILL SCHOOL DISTRICT 3] MAIN GAS
 Component
Gasoline
 Fluid
GASOLINE (10000 GAL)

DIAGNOSIS

Recommendation

Please note that gasoline evaluation is outside the scope of our normal laboratory tests.

Contamination

The water content is negligible. There is no indication of any contamination in the gasoline.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0957776	---	---
Sample Date	Client Info		25 Jun 2024	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			NORMAL	---	---



CONTAMINANTS

	method	limit/base	current	history1	history2
Water	%	ASTM D6304	0.001	---	---
ppm Water	ppm	ASTM D6304	13	---	---

VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual		NEG	---
Free Water	scalar	*Visual		NEG	---


SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



OIL ANALYSIS REPORT

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0957776

Lab Number : 06220307

Unique Number : 11098504

Test Package : TEST (Additional Tests: API, CC Flash, Cetane, Color-ASTM, GC-PercFuel, GCD, ICP, KF, KV40, PrtCoun

Received : 25 Jun 2024

Tested : 02 Jul 2024

Diagnosed : 02 Jul 2024 - Doug Bogart

PETROLEUM RECOVERY SERVICES

210 POWELL DR

SUMMERVILLE, SC

US 29483

Contact: AJAY EL

Ajay@prsfuel.com

T: (843)225-1777

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)