




COOLANT REPORT

Sample Rating Trend



NORMAL



Area
[PMIAS3429604]
 Machine Id
4001084 (S/N 2094562)
 Component
Coolant
 Fluid
50/50 (--- QTS)

DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORMATION


	method	limit/base	current	history1	history2
Sample Number	Client Info		DC0037040	DC0031913	DC0026702
Sample Date	Client Info		14 Jun 2024	06 Dec 2023	22 May 2023
Machine Age	mls	Client Info	194	182	174
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	Not Changd	N/A
Sample Status			NORMAL	NORMAL	NORMAL

PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		1.068	1.068	1.068
pH	Scale 0-14 ASTM D1287		9.65	9.26	9.51
Nitrites	ppm AP-053:2009		1200	976	900
Reserve Alkalinity	Scale 0-20 *ASTM D1121		---	---	---
Percentage Glycol	% ASTM D3321		50.5	50.9	50.8
Freezing Point	°F ASTM D3321		-35	-35	-35
Total Dissolved Solids			230.5	169.0	215.0
Carboxylate			n/a	n/a	n/a


VISUAL

	method	limit/base	current	history1	history2
Coolant Color	*Visual		Orange	Orange	Yllow
Coolant Appearance	*Visual	Clear	normal	normal	hazy











COOLANT REPORT



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : DC0037040

Lab Number : 06220325

Unique Number : 11098522

Test Package : COOL- (Additional Tests: GlycolType)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 25 Jun 2024

Tested : 27 Jun 2024

Diagnosed : 27 Jun 2024 - Jonathan Hester

KELLY GENERATOR & EQUIPMENT INC

1955 DALE LN

OWINGS, MD

US 20736

Contact: LESLIE SNURR

LSNURR@KGE.COM

T: (410)257-5225

F: (410)257-5227