

# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 7196037 (S/N 1471)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

## Contamination

There is a moderate amount of particulates present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul202	1 Feb 2022	Jun2023 Ju	n2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA019375	KCP53682	KCP35113
Sample Date		Client Info		19 Jun 2024	01 Jun 2023	12 Feb 2022
Machine Age	hrs	Client Info		23386	17655	8301
Oil Age	hrs	Client Info		2385	5734	3270
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	13	5	3
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	2
Barium	ppm	ASTM D5185m	90	<1	41	41
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	0	51	51
Calcium	ppm	ASTM D5185m	0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	1	0	0
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	23500	21199	22000	17235
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		2	2	8
Potassium	ppm	ASTM D5185m	>20	1	0	<1
Water	%	ASTM D6304	>0.05	0.006	0.030	0.011
ppm Water	ppm	ASTM D6304	>500	68	301.0	114.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4346	15024	10830
Particles >6µm		ASTM D7647	>1300	<b>1506</b>	<b>4</b> 067	▲ 3335
Particles >14μm		ASTM D7647	>80	<b>101</b>	▲ 302	▲ 321
Particles >21µm		ASTM D7647	>20	<b>40</b>	<b>▲</b> 82	<b>△</b> 93
Particles >38μm		ASTM D7647	>4	4	3	<u>\$</u> 5
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>19/18/14</b>	<u>\$\text{\Delta}\$ 21/19/15</u>	<b>△</b> 19/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



# **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory

Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06220377 Unique Number : 11098574

: KCPA019375

**Tested** : 26 Jun 2024 Diagnosed : 27 Jun 2024 - Don Baldridge Test Package : IND 2 ( Additional Tests: KF, PrtCount )

Received

: 25 Jun 2024

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**RURAL WATER DISTRICT #8** 

100 N SHANNON ST WAYNE, OK US 73095

Contact: DISTRICT 8 ruralwaterdistrict8@yahoo.com

T: F:

Report Id: RURWAY [WUSCAR] 06220377 (Generated: 06/27/2024 12:53:43) Rev: 1

Contact/Location: DISTRICT 8 ? - RURWAY