




FUEL REPORT

Sample Rating Trend



NORMAL



Area
MUSC Columbia - Downtown [18596]
 Machine Id
[MUSC Columbia - Downtown] KOHLER
 Component
Diesel Fuel
 Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (300 GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC06220598	WC06179669	---
Sample Date	Client Info	17 Jun 2024	07 May 2024	---
Machine Age	hrs	Client Info	0	0
Sample Status			NORMAL	ABNORMAL

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2	
Fuel Color	text	*Visual Screen	Yellow	Red	Red
ASTM Color	scalar	*ASTM D1500		L4.5	L4.0
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	61.7	62.5

SULFUR CONTENT

method	limit/base	current	history1	history2	
Sulfur	ppm	ASTM D5185m	10	0	54
Sulfur (UVF)	ppm	ASTM D5453		37	50

DISTILLATION

method	limit/base	current	history1	history2	
Initial Boiling Point	°C	ASTM D86	165	173	174
5% Distillation Point	°C	ASTM D86		196	196
10% Distill Point	°C	ASTM D86	201	206	206
15% Distillation Point	°C	ASTM D86		214	214
20% Distill Point	°C	ASTM D86	216	222	222
30% Distill Point	°C	ASTM D86	230	236	236
40% Distill Point	°C	ASTM D86	243	249	249
50% Distill Point	°C	ASTM D86	255	261	262
60% Distill Point	°C	ASTM D86	267	275	275
70% Distill Point	°C	ASTM D86	280	288	289
80% Distill Point	°C	ASTM D86	295	303	304
85% Distillation Point	°C	ASTM D86		314	315
90% Distill Point	°C	ASTM D86	310	325	326
95% Distillation Point	°C	ASTM D86		343	344
Final Boiling Point	°C	ASTM D86	341	359	360

IGNITION QUALITY






method	limit/base	current	history1	history2	
API Gravity		ASTM D7777	37.7	37	37
Cetane Index		ASTM D4737	<40.0	50	49

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	<1.0	<1	0
Sodium	ppm	ASTM D5185m	<0.1	<1	<1
Potassium	ppm	ASTM D5185m	<0.1	0	0
Water	%	ASTM D6304	<0.05	0.006	▲ 0.058
ppm Water	ppm	ASTM D6304	<500	66	▲ 584
% Gasoline	%	*In-House	<0.50	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0




FUEL REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	1099	---	---
Particles >6µm	ASTM D7647	>640	213	---	---
Particles >14µm	ASTM D7647	>80	4	---	---
Particles >21µm	ASTM D7647	>20	1	---	---
Particles >38µm	ASTM D7647	>4	0	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	17/15/9	---	---

HEAVY METALS	method	limit/base	current	history1	history2	
Aluminum	ppm	ASTM D5185m	<0.1	0	0	---
Nickel	ppm	ASTM D5185m	<0.1	0	0	---
Lead	ppm	ASTM D5185m	<0.1	0	0	---
Vanadium	ppm	ASTM D5185m	<0.1	0	0	---
Iron	ppm	ASTM D5185m	<0.1	0	0	---
Calcium	ppm	ASTM D5185m	<0.1	0	3	---
Magnesium	ppm	ASTM D5185m	<0.1	<1	0	---
Phosphorus	ppm	ASTM D5185m	<0.1	<1	4	---
Zinc	ppm	ASTM D5185m	<0.1	0	<1	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					







no image

no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC06220598 **Received** : 25 Jun 2024
Lab Number : **06220598** **Tested** : 02 Jul 2024
Unique Number : 11098795 **Diagnosed** : 02 Jul 2024 - Doug Bogart
Test Package : DF-2 (Additional Tests: Fuel, Screen)

PETROLEUM RECOVERY SERVICES
 210 POWELL DR
 SUMMERVILLE, SC
 US 29483
 Contact: AJAY EL
 Ajay@prsfuel.com
 T: (843)225-1777
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)