


FUEL REPORT

BISHOP GADSDEN EPOSCOPAL RETIREMENT COMMUNITY [5018] [BISHOP GADSDEN EPOSCOPAL RETIREMENT COMMUNITY] HOLDING

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR





DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. There is too much contamination present in this sample to perform a particle count.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Appearance is hazy. Excessive free water present. High concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

R) (500 GAL)			,	Jun 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0957784		
Sample Date		Client Info		25 Jun 2024		
Machine Age	hrs	Client Info		0		
Sample Status				SEVERE		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	71.9		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		14		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	183		
5% Distillation Point	°C	ASTM D86		201		
10% Distill Point	°C	ASTM D86	201	210		
15% Distillation Point	°C	ASTM D86		217		
20% Distill Point	°C	ASTM D86	216	225		
30% Distill Point	°C	ASTM D86	230	239		
40% Distill Point	°C	ASTM D86	243	251		
50% Distill Point	°C	ASTM D86	255	264		
60% Distill Point	°C	ASTM D86	267	278		
70% Distill Point	°C	ASTM D86	280	291		
80% Distill Point	°C	ASTM D86	295	306		
85% Distillation Point	°C	ASTM D86		317		
90% Distill Point	°C	ASTM D86	310	328		
95% Distillation Point	°C	ASTM D86		345		
Final Boiling Point	°C	ASTM D86	341	361		
IGNITION QUALIT	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36		
Cetane Index		ASTM D4737	<40.0	49		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	< 0.1	0		
Water	%	ASTM D6304	< 0.05	0.014		
ppm Water	ppm	ASTM D6304	< 500	143		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		
MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	0		
Yeast	CFU/ml	WC-Method	>=100000	0		
Mold	Colonies	WC-Method	MODER			



FUEL REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06220616

: WC0957784

Unique Number : 11098813

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Tested

: 25 Jun 2024 : 02 Jul 2024 Diagnosed : 02 Jul 2024 - Doug Bogart

Test Package: DF-2 (Additional Tests: Bacteria, Fuel, Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)



210 POWELL DR SUMMERVILLE, SC US 29483

Contact: AJAY EL Ajay@prsfuel.com T: (843)225-1777

Contact/Location: AJAY EL - PETSUM