


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 7280065 (S/N 1022)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Aug2022 Jan2024 Jan2024						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC128635	KC125844	KC95206
Sample Date		Client Info		18 Jun 2024	24 Jan 2024	22 Aug 2022
Machine Age	hrs	Client Info		5831	5270	3686
Oil Age	hrs	Client Info		2151	0	2113
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	2	2
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	6	5	9
Tin	ppm	ASTM D5185m	>10	0	0	1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	<1	<1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	23	39	25
Calcium	ppm	ASTM D5185m	2	0	2	0
Phosphorus	ppm	ASTM D5185m		<1	0	2
Zinc	ppm	ASTM D5185m		14	0	11
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		9	11	10
Potassium	ppm	ASTM D5185m	>20	2	3	0
Water	%	ASTM D6304	>0.05	0.013	▲ 0.218	0.018
ppm Water	ppm	ASTM D6304	>500	137	<u>▲</u> 2180	186.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		16032		1482
Particles >6µm		ASTM D7647	>1300	<u> </u>		300
Particles >14µm		ASTM D7647	>80	<u> </u>		18
Particles >21µm		ASTM D7647	>20	<u> </u>		5
Particles >38μm		ASTM D7647	>4	0		0
Particles >71μm		ASTM D7647	>3	0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/20/15		18/15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34	0.32	0.27



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No. Lab Number

: KC128635 : 06221209 Unique Number : 11099406 Test Package : IND 2

Received : 26 Jun 2024 **Tested** : 27 Jun 2024

Diagnosed

: 27 Jun 2024 - Don Baldridge

13769 MARNE RD NEWARK, OH US 43055

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: