


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER 8389035 (S/N 1319)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **DIAGNOSIS**

### Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

All component wear rates are normal.

### Contamination

Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. Excessive free water present.

### **Fluid Condition**

The AN level is acceptable for this fluid.

		Aug2022	Dec2022 Apr2023	Sep2023 Jan2024	Jun2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129032	KC121852	KC125361
Sample Date		Client Info		04 Jun 2024	29 Jan 2024	14 Sep 2023
Machine Age	hrs	Client Info		13626	11607	9333
Oil Age	hrs	Client Info		2019	0	0
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	6
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	3	0	7
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	7	9
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	<1	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	5	0	<1
Calcium	ppm	ASTM D5185m	2	0	0	<1
Phosphorus	ppm	ASTM D5185m		18	0	121
Zinc	ppm	ASTM D5185m		29	0	108
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		2	0	0
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.05	<u>0.144</u>	0.004	▲ 0.218
ppm Water	ppm	ASTM D6304	>500	<u> </u>	46	▲ 2180
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			26428	
Particles >6µm		ASTM D7647	>1300		<u>▲</u> 10744	
Particles >14μm		ASTM D7647	>80		<u>▲</u> 1313	
Particles >21µm		ASTM D7647	>20		<b>426</b>	
Particles >38μm		ASTM D7647	>4		<u> </u>	
Particles >71μm		ASTM D7647	>3		2	
Oil Cleanliness		ISO 4406 (c)	>/17/13		<b>△</b> 22/21/18	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.09


0.37


0.48



## **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	<b>0.2%</b>	NEG	<b>△</b> 0.2%
Free Water	scalar	*Visual		<u> </u>	NEG	0.0
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	45.7	39.5	45.9

SAMPLE IMAGES

method limit/base

current


history1


history2


Color


**Bottom** 















Certificate 12367

Laboratory Sample No.

: KC129032 Lab Number : 06221242 Unique Number : 11099439 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 26 Jun 2024 **Tested** : 27 Jun 2024

Diagnosed : 27 Jun 2024 - Don Baldridge

**WICKETT & CRAIG** 120 COOPER RD CURWENSVILLE, PA US 16833

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - WICCURPA

T:

F: