

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

1432640 (S/N 3611920)

Component Compressor

QUINCY (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | | | | | , |
|------------------|------------|---------------|------------|-------------------|----------|----------|
| | | | | Jun2024 | | |
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | KCPA018096 | | |
| Sample Date | | Client Info | | 19 Jun 2024 | | |
| Machine Age | hrs | Client Info | | 15899 | | |
| Oil Age | hrs | Client Info | | 0 | | |
| Oil Changed | 1113 | Client Info | | Changed | | |
| Sample Status | | Ollerit IIIIO | | ABNORMAL | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| | | | | | HISTOTYT | HISTOLYZ |
| Iron | ppm | ASTM D5185m | >50 | 0 | | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | | |
| Nickel | ppm | ASTM D5185m | >3 | 0 | | |
| Titanium | ppm | ASTM D5185m | >3 | 0 | | |
| Silver | ppm | ASTM D5185m | >2 | 0 | | |
| Aluminum | ppm | ASTM D5185m | >10 | 0 | | |
| Lead | ppm | ASTM D5185m | >10 | 0 | | |
| Copper | ppm | ASTM D5185m | >50 | 2 | | |
| Tin | ppm | ASTM D5185m | >10 | 0 | | |
| Vanadium | ppm | ASTM D5185m | | 0 | | |
| Cadmium | ppm | ASTM D5185m | | 0 | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | | |
| Barium | ppm | ASTM D5185m | | <1 | | |
| Molybdenum | ppm | ASTM D5185m | | 0 | | |
| Manganese | ppm | ASTM D5185m | | <1 | | |
| Magnesium | ppm | ASTM D5185m | | 0 | | |
| Calcium | ppm | ASTM D5185m | | 0 | | |
| Phosphorus | ppm | ASTM D5185m | | 0 | | |
| Zinc | ppm | ASTM D5185m | | 10 | | |
| Sulfur | ppm | ASTM D5185m | | 104 | | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 5 | | |
| Sodium | ppm | ASTM D5185m | | 3 | | |
| Potassium | ppm | ASTM D5185m | >20 | <1 | | |
| Water | % | ASTM D6304 | >0.05 | 0.006 | | |
| ppm Water | ppm | ASTM D6304 | >500 | 66 | | |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | | 9101 | | |
| Particles >6µm | | ASTM D7647 | >1300 | <u>^</u> 2957 | | |
| Particles >14µm | | ASTM D7647 | >80 | <u> </u> | | |
| Particles >21µm | | ASTM D7647 | >20 | <u>^</u> 22 | | |
| Particles >38µm | | ASTM D7647 | >4 | 0 | | |
| Particles >71µm | | ASTM D7647 | >3 | 0 | | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | <u>^</u> 20/19/14 | | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Asid Number (AN) | ma 1/011/a | ACTM DODAE | | 0.20 | | 5.61 72 |


Acid Number (AN)

mg KOH/g ASTM D8045

0.29



OIL ANALYSIS REPORT





Report Id: INLHAY [WUSCAR] 06221244 (Generated: 06/27/2024 17:14:53) Rev: 1

Laboratory Sample No.

: KCPA018096 Lab Number

: 06221244 Unique Number : 11099441

Received : 26 Jun 2024 **Tested** Diagnosed

: 27 Jun 2024 : 27 Jun 2024 - Don Baldridge 3245 DEPOT RD HAYWARD, CA US 94545

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Contact: G HERNANDEZ GHERNANDEZ@INLANDMETAL.COM T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: G HERNANDEZ - INLHAY

F: