


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER CSD 100S 7765990 (S/N 1072)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA019342	KCP47595	
Sample Date		Client Info		14 Jun 2024	08 Nov 2022	
Machine Age	hrs	Client Info		15107	5258	
Oil Age	hrs	Client Info		3000	5258	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	10	17	
Tin	ppm	ASTM D5185m	>10	3	7	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	1	
Magnesium	ppm	ASTM D5185m	90	0	11	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		0	11	
Zinc	ppm	ASTM D5185m		0	11	
Sulfur	ppm	ASTM D5185m		22315	17505	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		2	3	
Potassium	ppm	ASTM D5185m	>20	<1	2	
Water	%	ASTM D6304	>0.05	0.010	0.013	
ppm Water	ppm	ASTM D6304	>500	101	139.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			10529	
Particles >6µm		ASTM D7647	>1300		▲ 3010	
Particles >14µm		ASTM D7647	>80		4 08	
Particles >21µm		ASTM D7647	>20		<u>109</u>	
Particles >38µm		ASTM D7647	>4		<u>8</u>	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		1 21/19/16	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.40	0.35	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory

Sample No.

Lab Number : 06221247

: KCPA019342 Unique Number : 11099444

Received **Tested**

: 26 Jun 2024 : 27 Jun 2024 Diagnosed

: 27 Jun 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

CLANTON, AL Contact: JONATHON PAYNE

jonathon.d.payne@adient.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2541 7TH ST S

US 35046

T:

F: