Sullivan Palatek

OIL ANALYSIS REPORT

Area ULTRA 46 [3506] INGERSOLL RAND EP-50-PE-125 PG0174403205 Component

Component Compressor

DIAGNOSIS

Recommendation

We advise that you check all areas where dirt can enter the system. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCS06221332	UCS06078411	UCS05985669
Sample Date		Client Info		14 Jun 2024	09 Jan 2024	22 Sep 2023
Machine Age	hrs	Client Info		18051	15004	1350
Oil Age	hrs	Client Info		8076	5029	3526
Oil Changed		Client Info		Changed	Not Changd	Changed
Sample Status				ATTENTION	ATTENTION	ATTENTION
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>5	<1	0	<1
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>15	2	<1	2
Lead	ppm	ASTM D5185m	>65	0	2	0
Copper	ppm	ASTM D5185m	>65	0	2	<1
Tin	ppm	ASTM D5185m	>10	0	1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	500	0	0	7
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m		0	2	0
Magnesium	ppm	ASTM D5185m	0	<1	<1	<1
Calcium	ppm	ASTM D5185m	0	0	<1	2
Phosphorus	ppm	ASTM D5185m	20	123	142	133
Zinc	ppm	ASTM D5185m	0	69	88	84
Sulfur	ppm	ASTM D5185m	200	218	180	171
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	67	37	40
Sodium	ppm	ASTM D5185m		0	3	0
Potassium	ppm	ASTM D5185m	>20	1	3	2
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.65	0.44	0.097

OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	49.4	46.3	46.1	46.5
SAMPLE IMAGES	3	method	limit/base	current	history1	history2

Color



Bottom





 Vietnes/Lueence
 Unique Number
 : 11099529
 Diagnosed
 : 27 Jun 2024 - Sean Felton

 Certificate L2367
 Test Package
 : IND 2
 Cont

 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 dd

 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1002 DOBBINS MILL RD ELKIN, NC US 28621 Contact: DARRYL WEDDLE darryl@stanleyhvac.com T: (336)366-4226 :2012) F:

Report Id: UCSTAELK [WUSCAR] 06221332 (Generated: 06/30/2024 17:40:04) Rev: 1

Contact/Location: DARRYL WEDDLE - UCSTAELK