

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area ULTRA FG GARDNER DENVER S067011

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2	
Sample Number		Client Info	JHF0000406		UCH06065750		
Sample Date		Client Info		19 Jun 2024	18 Jan 2024		
Machine Age	hrs	Client Info		79898	0		
Oil Age	hrs	Client Info		500	0		
Oil Changed		Client Info		Not Changd	N/A		
Sample Status				NORMAL	NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2	
Water		WC Method	>0.1	NEG	NEG		
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0		
Chromium	ppm	ASTM D5185m	>10	<1	0		
Nickel	ppm	ASTM D5185m		0	0		
Titanium	ppm	ASTM D5185m		0	0		
Silver	ppm	ASTM D5185m		0	0		
Aluminum	ppm	ASTM D5185m	>25	2	0		
Lead	ppm	ASTM D5185m	>25	0	0		
Copper	ppm	ASTM D5185m	>50	6	<1		
Tin	ppm	ASTM D5185m	>15	0	0		
Vanadium	ppm	ASTM D5185m		0	<1		
Cadmium	ppm	ASTM D5185m		0	0		
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0		
Barium	ppm	ASTM D5185m		1	24		
Molybdenum	ppm	ASTM D5185m		0	0		
Manganese	ppm	ASTM D5185m		0	<1		
Magnesium	ppm	ASTM D5185m		2	0		
Calcium	ppm	ASTM D5185m		28	39		
Phosphorus	ppm	ASTM D5185m		381	413		
Zinc	ppm	ASTM D5185m		16	8		
Sulfur	ppm	ASTM D5185m		549	624		
CONTAMINANTS	;	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	0	0		
Sodium	ppm	ASTM D5185m		8	8		
Potassium	ppm	ASTM D5185m	>20	2	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.22	0.17		




Bas 45

Abnorm 40 Jan 18/24

OIL ANALYSIS REPORT

VISUAL



	White Metal	scalar	*Visual	NONE	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE	NONE		
	Debris	scalar	*Visual	NONE	LIGHT	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE		
9/24 -	Appearance	scalar	*Visual	NORML	NORML	NORML		
Jun19/24	Odor	scalar	*Visual	NORML	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG		
	Free Water	scalar	*Visual		NEG	NEG		
1	FLUID PROPERT	TIES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445	46.0	50.9	51.0		
******	SAMPLE IMAGES	S	method	limit/base	current	history1	history2	
Jun19,24	Color				•		no image	
	Bottom						no image	
	GRAPHS							
	Ferrous Alloys							
	10 iron							
	o announce chromium							
	2							
	0							
	Jan 18/24			Jun19/24.				
	Jan 1			Jun1				
	Non-ferrous Metal	s						
	8 - copper							
	E 6		and the second sec	CCCCCC.				
	2	STOCCO CONTRACTOR						
	8/24			9/24				
	Jan 18/24			Jun19/24				
	Viscosity @ 40°C				Acid Numb	or		
	60 Abnormal							
	55 -			HOX 0.20				
	(0.04) 50 Base			Ë 0.15				
	S So Base			ag 0.10				
	Abnormal			(0,25 (0,10) (0,10) (0,15) (0,10) (0,15) (0,10) (0,15) (0,10) (0,15) (0,10) (0,15) (0,10) (0,15) (0,10) (0,15) (0,15) (0,15) (0,15) (0,15) (0,15) (0,15) (0,16) (0,15) (0,16) (0,	1			
	40			0.00	-		24	
	Jan 18/24			Jun 19/24	Jan 18/24		Jun19/24	
	: WearCheck USA - 50 : JHF0000406 : 06221372	Recei Teste	Madison Ave., Cary, NC 27513 Received : 26 Jun 2024 Tested : 27 Jun 2024 Diagnosed : 27 Jun 2024 - Wes Davis			JOHN HENRY FOSTER COMPANY 4700 LEBOURGET STREET SAINT LOUIS, MO US 63134		
67 Test Package		-				Contact: RACHEL		
ss this sample report,	contact Customer Servi						atten@jhf.com	
	are outside of the ISO 1	7025 sco	pe of accreo	litation		T	(314)593-126	

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCJOHSAI [WUSCAR] 06221372 (Generated: 06/29/2024 01:57:09) Rev: 1

Contact/Location: RACHEL VON HATTEN - UCJOHSAI

Page 2 of 2

F: (314)874-0965